MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT
14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

AUTHORITY TO CONSTRUCT N015711

If construction is not completed by the expiration date of this permit, it may be renewed for one additional year upon payment of applicable fees. Any additional extension will require the written approval of the Air Pollution Control Officer. This Authority to Construct may serve as a temporary Permit to Operate provided the APCO is given prior notice of intent to operate and the Permit to Operate is not specifically denied.

EXPIRES LAST DAY OF: MAY 2027

OWNER OF OPERATOR (Co.#199)

SBCo Fleet Management Department
210 N Lena Road
San Bernardino, CA 92415-0842

EQUIPMENT LOCATION (Fac.#4224)

SBCo - Trona Road Yard
80311 Trona Road
Trona, CA 93562

Description:
GASOLINE DISPENSING FACILITY (NON-RETAIL) consisting of: One Supervault MH Model MH-D5-10000 aboveground gasoline storage tank (AST), each with a capacity of 10,000 gallons, equipped with an Morrison Brothers Phase I Vapor Recovery System. NOTE: Facility claims that this fueling equipment is to be used with ORVR fleet/vehicles and is therefore exempt from Phase II EVR standards. There is also one Diesel underground storage tank (UST) with a capacity of 10,000 gallons (exempt from permitting, pursuant to MD Rule 219(E)(15)(c)(iii)). Facility Elevation is 1646 feet above MSL.

FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
1	87U	10,000	Above Ground
2	Diesel	10,000	Above Ground

DISPENSING EQUIPMENT

Fuel Type	Quantity
87U	1

VAPOR CONTROL EQUIPMENT

Fee Schedule: 5 (a) Rating: 10000 gallons SIC: 9199 SCC: 40600601 Location/UTM(Km): 466E/3957N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

SBCo Fleet Management Department
210 N Lena Road
San Bernardino, CA 92415-0842

By: **COPY**
Brad Poiriez
Executive Director

UNOFFICIAL

Type	Equipment Name	Compliance
SL	SL	VR-302
PI	MB	VR-402

CONDITIONS:

1. The owner/operator shall conspicuously post, in the gasoline dispensing area, the operating instructions and the district's toll-free telephone number for complaints (1-800-635-4617).
[District Rule 461 - Gasoline Transfer and Dispensing]

2. The owner/operator shall maintain a log of all inspections, maintenance and repairs, and throughput on equipment. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.
[District Rule 461 - Gasoline Transfer and Dispensing]

3. The owner/operator has elected to maintain this equipment as exempt from Phase II Enhanced Vapor Recovery requirements by refueling a fleet with at least 95%+ ORVR vehicles. To ensure compliance the owner/operator shall keep records of the make, model, model year, and Vehicle Identification number of all vehicles refueled at the facility. These records shall be maintained on the premises for at least two (2) calendar years.
[District Rule 461(D)(3) and (E)(6) - Gasoline Transfer and Dispensing]

4. Any modifications or changes to the piping, control fittings, or configurations of the vapor recovery system require prior approval from the District.
[District Regulation XIII - NSR]

5. Pursuant to California Health and Safety Code sections 39600, 39601, and 41954, this aboveground tank shall be installed and maintained in accordance with Executive Order (EO) VR-402 Morrison Brothers for EVR Phase I. The gasoline vapor vent pipes are to be equipped with Husky 5885 pressure relief valves or as otherwise allowed by Executive Order (EO) VR-302.
[CARB Executive Order VR-302]

6. The Enhanced Vapor Recovery (EVR), Phase I Vapor Recovery System must be tested in accordance with the requirements of CARB Executive Order VR-402, no later than 60 days after initial startup, and at least once every twelve (12) months using the latest adopted version of the required test procedures.

The District must be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests. Testing notifications and testing results may be sent to VaporRecoveryTesting@mdaqmd.ca.gov
[District Rule 461 - Gasoline Transfer and Dispensing, Executive Order VR-402]

7. The annual throughput of gasoline shall not exceed 480,000 gallons per year. Throughput records shall be kept on site and available to District personnel upon request, and annual throughput for the previous calendar year shall be provided to the District not later than the end of February of each year. Before this annual throughput can be increased the facility is required to submit to the District an application to modify the permit which may require a Health Risk Assessment (HRA). In addition, public notice and/or a commenting period may be required.
[District Rule 1320; District Rule 107(b); H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]

8. The owner/operator must install, maintain, and operate this equipment in compliance with these permit conditions and 40 CFR Part 63 Subpart CCCCCC. In the event of conflict the more stringent requirements shall govern.
[District Rule 1302]

9. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.
[District Rule 107(b); H&S Code 39607 & 44341-44342, 17 CCR 93400 et seq., and 40 CFR 51, Subpart A]