



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

S004560

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: NOVEMBER 2004

OWNER OF OPERATOR (Co.#87)

Commanding Officer, MCLB Barstow, CA
Box 110570 Bldg 196 Attn: Air Program Manager
Barstow, CA 92311-5050

EQUIPMENT LOCATION (Fac.#587)

USMC MCLB - Yermo Annex
USMC Logistics Base
Barstow, CA 923115013

Description:

PAINT SPRAY BOOTH (Bldg 573, Area 11) consisting of: Booth #3, SBS Special Model No. TEL 1486-100 (modified).

EQUIPMENT

Capacity	Equipment Description
0	Dimensions: 10' h x 22' w x 12' deep
0	Intake Filters: 78, 20"x 20"x2"
0	Exhaust Filters: 60, 20"x20", Air Technologies, Inc., high efficiency
0	Total Air Flow Rate: 22,000 cfm; 15,000 cfm to APC device (C004561) and 7,000 cfm recirculated back to the booth by two 15" variable frequency drive fans.

CONDITIONS:

1. The owner/operator (o/o) shall operate this equipment in strict accord with the manufacturer's specifications and/or sound engineering principles.
2. This spray booth shall be operated in compliance with District rules 1115 and 1116.

Fee Schedule: 7 (i)

Rating: 1 device

SIC: 9711

SCC: 9999999

Location/UTM(Km):
512E/3861N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Commanding Officer, MCLB Barstow, CA
Box 110570 Attn: Air Program Manager
Barstow, CA 92311-5050

By: **COPY**
Brad Poiriez
Executive Director

3. This spray booth shall not be operated unless it is vented to the operating APCS covered by District permit C004561.

NOTE: This booth after the rebuild or modification is complete for the air recirculation system may be used in the conventional manner (with filters, no recirculation and exhaust to atmosphere) until the APCS covered by District permit C004561 is constructed and operational.

4. If the emergency bypass sequence is activated, the event shall be reported to the District in accordance with District rule 430.

5. This spray booth and the booth covered by District permit S004559 shall have an interlock system that prevents painting in both booths at the same time.

6. This spray booth shall be equipped with a guage to measure the static pressure differential across the three stage high efficiency exhaust filters. In operation, the pressure differential shall not exceed 2.5 inches of water.