



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

T000109

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: JULY 2014

OWNER OF OPERATOR (Co.#2)

CALNEV Pipe Line, LLC
1001 Louisiana Street
Houston, TX 77002-5089

EQUIPMENT LOCATION (Fac.#255)

CALNEV - George Terminal
Air Expressway, East of Phantom
Victorville, CA 92394

Description:

TANK consisting of: JP-8 Jet Fuel Storage, 20,140 barrels (845,880 gallons) capacity, pontoon-type floating roof and seal augmenters. Tank No. 211. Total - 845,880 gallons.

CONDITIONS:

1. There shall be no holes, tears, or openings in the primary seal which allow the uncontrolled emission of VOC.
2. Gaps between the tank shell and the primary seal shall not exceed 1/8" for an accumulative length of 95% of the seal circumference and shall not exceed 1/2 " for the remaining 5% of accumulative length.
3. All gauge hatches, roof supports, manholes, automatic bleeder vents, rim vents, gauge wells, etc., shall be equipped with vapor-tight seals or breather vents set at no less than 10% of the maximum allowable working pressure of the roof.
4. All openings in the tank roof shall be equipped with a projection which extends below the liquid surface.
5. Emergency roof drain shall be equipped with slotted membrane fabric cover, or equivalent, which covers at least 90% of the drain area.

Fee Schedule: 5 (c)

Rating: 846000 gallons

SIC: 5171

SCC: 99999999

Location/UTM(Km):
466E/3826N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

CALNEV Pipe Line, LLC
1001 Louisiana Street

Houston, TX 77002-5089

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

6. The permittee shall maintain an accurate record of the storage temperature of liquid stored in this tank; this record shall be maintained for a minimum of two years and shall be made available to District personnel upon request. True vapor pressure of liquids stored shall not exceed 11.0 psia.

7. Equipment shall be maintained and operated in accordance with local and state certification requirements.

8. The permittee shall perform all inspections and maintain records required in District rule 463.