



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

T002176

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: DECEMBER 1999

OWNER OF OPERATOR (Co. #248)

Sunray Energy, Inc
35100 E Santa Fe Road
Daggett, CA 92327

EQUIPMENT LOCATION (Fac. #899)

Sunray Energy - SEGS I
35100 E Santa Fe Road
Daggett, CA 92327

Description:

HTF STORAGE TANK consisting of: Light end liquid, 2000 gallon - steel above ground.

CONDITIONS:

1. This tank stores HTF Light Ends (the condensible fraction of the vapors vented from the ullage system) liquid that may be burned in the Standby Oil Heater (B002162). This tank must be properly maintained.
2. If current non-criteria substances become regulated as toxic or hazardous substances and are used in this equipment, the owner/operator (o/o) shall submit to the District a plan demonstrating how compliance will be achieved and maintained with such regulations.

Fee Schedule: 5 (a)

Rating: 2000 gallons

SIC: 4911

SCC: 99999999

Location/UTM(Km):
515E/3858N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Sunray Energy, Inc
PO Box 338
Daggett, CA 92327

By: **COPY**
Eldon Heaston
Air Pollution Control Officer