



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

T002187

---

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: APRIL 2001**

---

**OWNER OF OPERATOR (Co.#69)**

Southern California Edison  
P.O. Box 5085  
Rosemead, CA 91770

**EQUIPMENT LOCATION (Fac.#902)**

SCE - Barstow Service Center  
1820 Rimrock Road  
Barstow, CA 92311

**Description:**

WASTE OIL STORAGE TANK consisting of: 1,000 gallons, underground with submerged fill.

**CONDITIONS:**

1. Each petroleum product tank must be equipped with a permanent submerged fill pipe. A person shall not transfer or permit the transfer of petroleum products into this tank by any means other than the permanent submerged fill pipe.
2. Hazardous or toxic material other than internal combustion engine crankcase drainage oil shall not be stored in this tank.

Fee Schedule: 5 (a)

Rating: 1000 gallons

SIC: 4911

SCC: 40701614

Location/UTM(Km):  
501E/3859N

---

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

---

Southern California Edison  
P.O. Box 5085  
  
Rosemead, CA 91770

By: **COPY**  
**Brad Poiriez**  
Executive Director