



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**PERMIT TO OPERATE**

T002240

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

**EXPIRES LAST DAY OF: NOVEMBER 2026**

**OWNER OF OPERATOR (Co. #352)**

Pilot Travel Centers, LLC  
5508 Lonas Rd.  
Knoxville, TN 37909

**EQUIPMENT LOCATION (Fac. #1016)**

Pilot Travel Center #282  
2591 Commerce Parkway  
Barstow, CA 92311

**Description:**

TANK consisting of: 150,000 Gallon, Aboveground, Diesel fuel, bottom fill (submerged) 20,000 Gallon, Aboveground Bio-Diesel Fuel, bottom fill (submerged) Associated GDF Permit as G002259 Facility elevation is 2373 feet above sea level.

**CONDITIONS:**

1. This equipment shall be operated in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.

[District Rule 1302(C)(2)(a)]

2. This equipment shall be operated and maintained in strict accord with the recommendations of its manufacturer or supplier and/or sound engineering principles.

[District Rule 1302(C)(2)(a)]

3. All of the components of this tank, including but not limited to tanks, flanges, seals, pipes, pumps, valves, meters, connectors, shall be maintained and operated so as to prevent fugitive vapor leaks, fugitive liquid leaks, and excess organic liquid drainage during transfer, storage and handling operations.

[District Rule 463(C)(3)]

Fee Schedule: 5 (c)

Rating: 170000 gallons

SIC: 5541

SCC: 40400121

Location/UTM(Km):  
493E/3856N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Pilot Travel Centers, LLC  
5508 Lonas Drive  
  
Knoxville, TN 37909

By: **COPY**  
**Eldon Heaston**  
Air Pollution Control Officer

4. The owner/operator shall maintain a log of all inspections, repairs, and maintenance on equipment. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.

[District Rule 463]

5. The annual throughput of gasoline shall not exceed 50,000,000 gallons per year. Throughput records shall be kept on site and available to District personnel upon request, and annual throughput for the previous calendar year shall be provided to the District not later than the end of February of each year. Before this annual throughput can be increased the facility may be required to submit to the District a site specific Health Risk Assessment (HRA) in accord with a District approved plan. In addition a public notice and/or comment period may be required.

[District Rule 1320]

6. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]