MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT
14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

RENEWAL

T003308

Renewal type Permit has no description information.

EXPIRES LAST DAY OF: NOVEMBER 2026

OWNER OF OPERATOR (Co.#86)

MAGTFTC MCAGCC
Box 788110, Bldg 1418
Twentynine Palms, CA 92278-8110

EQUIPMENT LOCATION (Fac.#3252)

USMC AGCC - USMC Utilities
Box 788110, Bldg. 1451
Twentynine Palms, CA 92278

Description:
FUEL TANK FARM (BLDG 1577) consisting of: The following tanks and a circulating fuel pump powered by a 50 bhp electric motor.

EQUIPMENT

Capacity	Equipment Description
5	50,000 gallon Diesel Fuel Storage Tank (horizontal, 12' D by 60' L) - Tank No. 7
5	50,000 gallon Diesel Fuel Storage Tank (horizontal, 12' D by 60' L) - Tank No. 8
5	50,000 gallon Diesel Fuel Storage Tank (horizontal, 12' D by 60' L) - Tank No. 6
5	50,000 gallon Diesel Fuel Storage Tank (horizontal, 12' D by 60' L) - Tank No. 9
5	50,000 gallon Diesel Fuel Storage Tank (horizontal, 12' D by 60' L) - Tank No. 10
5	50,000 gallon Diesel Fuel Storage Tank (horizontal, 12' D by 60' L) - Tank No. 11

CONDITIONS:

1. Only Number 2 Diesel fuel or biodiesel B20 fuel shall be stored in this tank farm.

2. All flanges, seals, pumps and other appurtenant equipment shall be maintained to prevent loss of volatile fractions.

Fee Schedule: 5 (c) | Rating: 300000 gallons | SIC: 9711 | SCC: 99999999 | Location/UTM(Km): 587E/3788N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

MAGTFTC MCAGCC
Box 788110, Building 1418

Twentynine Palms, CA 92278-8110

By: **COPY**
Brad Poiriez
Executive Director

UNOFFICIAL

3. The owner/operator (o/o) shall maintain an operator's log of these tanks which as a minimum contains the daily throughput amount received and dispensed.

4. This equipment shall only be operated/maintained in strict accord with manufacturer's/supplier's recommendations and/or sound engineering principles.