

## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park AvenueVictorville, CA92392-2310 760.245.1661 -- 800.635.4617 -- FAX760.245.2022

## PERMIT TO OPERATE

T003332

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

## **EXPIRES LAST DAY OF: AUGUST 2026**

## OWNER OF OPERATOR (Co.#15)

Pacific Gas & Electric/Air Permits PO Box 28150 Oakland,CA94604-8150

#### **EQUIPMENT LOCATION (Fac. #535)**

PG&E - Hinkley Compressor Station 35863 Fairview Road Hinkley,CA92347

# **Description:**

TANK, WASTE OIL STORAGE consisting of: Welded steel 7,000 gal fixed roof cylindrical tank 8 ft in diameter and 18.42 ft high

#### **CONDITIONS:**

- 1. This tank is limited to storing IC engine waste oil generated on-site by Pacific Gas & Electric.
- 2.All flanges, seals, pumps and other appurtenant equipment shall be installed and maintained to prevenet the loss of volatile fractions.
- 3. The owner/operator (o/o) shall log all shipments of oil to other parties and the hauler of said oil. Additionally, this log shall contain the mass (or volume) and the date of the oil shipment.
- 4.The o/o shall keep the log on-site for a minimum of two (2) years and provide it to District personnel on request.

Fee Schedule:5 (a)

Rating:7000gallons

SIC:4939

SCC:30630006

Location/UTM(Km):485E/3862N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Pacific Gas & Electric/Air Permits PO Box 28150 Oakland, CA94604-8150

By: COPY
Brad Poiriez
Air Pollution Control Officer

Page 1 of 1 Permit: T003332 Issue Date: 07/28/2025