



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

T004503

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: AUGUST 2015

OWNER OF OPERATOR (Co.#15)

Pacific Gas & Electric/Air Permits
PO Box 28150
Oakland, CA 94604-8150

EQUIPMENT LOCATION (Fac.#535)

PG&E - Hinkley Compressor Station
35863 Fairview Road
Hinkley, CA 92347

Description:

TANK, PIPELINE LIQUID STORAGE consisting of: 6,130 gal Stainless Steel above ground tank, vented to the atmosphere with no controls or pressure-vacuum valves.

CONDITIONS:

1. The o/o shall construct, operate, and maintain this equipment in strict accord with the recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emission of contaminants practicable.
2. The o/o shall log the gallons of liquid disposed of from this tank in addition to the date of disposal. This log shall be maintained current, on-site for a minimum of five (5) years and provided to District, State or Federal personnel on request
3. The o/o shall only store waste liquids that accumulate in natural gas pipelines, which have a vapor pressure of less than 0.1 psi, and flash point of approximately 415 degrees Fahrenheit. Only pipeline liquids may be stored in this tank.
4. All flanges, seal pumps and other appurtenant equipment shall be maintained to prevent loss of volatile fractions.

Fee Schedule: 5 (a)

Rating: 6000 gallons

SIC: 4939

SCC: 40799998

Location/UTM(Km):
485E/3862N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Pacific Gas & Electric/Air Permits
PO Box 28150
Oakland, CA 94604-8150

By: **COPY**
Eldon Heaston
Air Pollution Control Officer