



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

### PERMIT TO OPERATE

T005103

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

**EXPIRES LAST DAY OF: SEPTEMBER 2025**

#### OWNER OF OPERATOR (Co. #22)

BNSF Railway Company  
740 East Carnegie Drive  
San Bernardino, CA 92408

#### EQUIPMENT LOCATION (Fac. #236)

BNSF Railway Co - Barstow  
200 North Avenue H  
Barstow, CA 92311

#### Description:

DIESEL FUEL STORAGE TANK consisting of: 114' diam x 30' high cone fixed roof tank, No. 1605, 2,310,000 Gallon (55,000 Bbl) capacity. Equipment elevation is 2183 feet above sea level.

#### CONDITIONS:

1. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles in a manner consistent with good air pollution control practice for minimizing emissions. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

[District Rule 1302(C)(2)(a)]

2. Only diesel fuel having a true vapor pressure less than 77.5 mm Hg (1.5 psi) absolute or greater under actual storage conditions can be stored in this tank. The District must be notified in writing prior to changing the type of product to be stored in this tank.

[District Rule 463, 1302 and 1520]

3. All of the components of this tank, including but not limited to the tank itself, flanges, seals, pipes, pumps, valves, meters, and connectors shall be maintained and operated so as to prevent fugitive vapor leaks, fugitive liquid leaks, and excess organic liquid drainage during transfer, storage and handling operations.

[District Rule 463(C)(3)]

Fee Schedule: 5 (d)

Rating: 2310000 gallons

SIC: 4013

SCC: 40400121

Location/UTM(Km): 493E/3861N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

BNSF Railway Company  
740 East Carnegie Dr

San Bernardino, CA 92408-3571

By: **COPY**

**Brad Poiriez**

Air Pollution Control Officer

4.The owner/operator shall maintain an operations log for this equipment, current and on-site (or at a central location) for a minimum of two (2) years, and this log shall be provided to District, State and/or Federal personnel, upon request. The log shall include, at a minimum, the information specified below:

- a. Copies of MSDS for the Diesel Fuel being stored.
  - b. A log containing any repairs and maintenance conducted on this equipment, as occurring.
- [District Rule 463 (D)(1) and (D)(3)]

5.A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]