



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

T007604

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: OCTOBER 2026

OWNER OF OPERATOR (Co. #352)

Pilot Travel Centers, LLC
5508 Lonas Rd.
Knoxville, TN 37909

EQUIPMENT LOCATION (Fac. #2220)

Flying J Travel Plaza #614
2611 Fisher Blvd
Barstow, CA 92311

Description:

DIESEL DISPENSING FACILITY (RETAIL) consisting of: four (4) 20,000 gallon aboveground diesel tanks, with 10 dispensers and 20 nozzles. See permit G007600 for gasoline dispensing. Facility Elevation is 740 meters above sea level.

EQUIPMENT

Capacity	Equipment Description
20000	Diesel Storage Tank #1
20000	Diesel Storage Tank #2
20000	Diesel Storage Tank #3
20000	Diesel Storage Tank #4 (Biodiesel)

CONDITIONS:

1. This equipment shall be operated in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.

[District Rule 1302(C)(2)(a)]

Fee Schedule: 5 (b)

Rating: 80000 gallons

SIC: 5541

SCC: 40600651

Location/UTM(Km):
498E/3862N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Pilot Travel Centers, LLC
5508 Lonas Drive

Knoxville, TN 37909

By: **COPY**
Brad Poiriez
Executive Director

2. This equipment shall be operated and maintained in strict accord with the recommendations of its manufacturer or supplier and/or sound engineering principles.

[District Rule 1302(C)(2)(a)]

3. Each petroleum product tank must be equipped with a permanent submerged fill pipe. A person shall not transfer or permit the transfer of petroleum products into this tank by any means other than the permanent submerged fill pipe.

4. All of the components of this tank, including but not limited to tanks, flanges, seals, pipes, pumps, valves, meters, connectors, shall be maintained and operated so as to prevent fugitive vapor leaks, fugitive liquid leaks, and excess organic liquid drainage during transfer, storage and handling operations.

[District Rule 463(C)(3)]

5. The owner/operator shall maintain a log of all inspections, repairs, and maintenance on equipment. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.

[District Rule 463]

6. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]