



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

T007861

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: DECEMBER 2016

OWNER OF OPERATOR (Co.#500)

ACE Cogeneration Company
12801 S Mariposa Street
Trona, CA 93562

EQUIPMENT LOCATION (Fac.#1051)

ACE Cogeneration Company
12801 S Mariposa Street
Trona, CA 93562

Description:

STORAGE BIN, SOLID FUEL consisting of: 300 ton fuel bin measuring 75' H x 20'. Capacity calculated at 300 gallons per ton, or 90,000 gallons. Insp Change Number: 2906 Permit Number: T007861 Inspector Name: Sarah Strout Engineer Name: Sam Oktay

CONDITIONS:

1. The installation and operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
[Rule 204 - Permit Conditions; Version in SIP = CARB Ex. Order G-73, 40 CFR 52.220(c)(39)(ii)(B) - 11/09/78 - 43 FR 52237; Current Rule Version = 07/25/77]
2. The o/o shall install, operate and maintain this dust collector in strict accord with those recommendations of the manufacturer/supplier, and sound engineering principles, which produce minimum emissions of air contaminants.
[Rule 1302(C)(2)(a), Version in SIP = CARB Ex. Order G-73, 40 CFR 52.220(c)(239)(i)(A)(1) 61 FR 58133; Current Rule Version = 08/26/06]
3. This equipment shall not be operated unless it is vented to the properly functioning air pollution control equipment covered by valid District permit C007862.
[MDAQM Rule 1303(A) BACT; SIP Version 3/25/1996; 40 CFR 52.220(c)(239)(i)(A)(1); Current Rule Version = 09/24/01]

Fee Schedule: 5 (b)

Rating: 90000 gallons

SIC: 4911

SCC: 30501011

Location/UTM(Km):
465E/3958N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

ACE Cogeneration Company
12801 S Mariposa Street
Trona, CA 93562

By: **COPY**
Brad Poiriez
Executive Director