



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

T008067

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: NOVEMBER 2025

OWNER OF OPERATOR (Co.#84)

NTC - Public Works
Bldg 602, 5th Street
Fort Irwin, CA 92310

EQUIPMENT LOCATION (Fac.#589)

NTC Training Mission
Bldg. 602, 5th street
Fort Irwin, CA 923105085

Description:

STORAGE TANKS (BLDG 630) consisting of:

EQUIPMENT

Capacity	Equipment Description
32000	4 tanks, 8000 gallons each, for storing waste oil and contaminated JP-8
0	2 tanks, 500 gallon each, for storing water drained from the waste oil tanks, listed above.

CONDITIONS:

1. These tanks are limited to storing waste oil specified in the application which is generated on-site
2. All flanges, seals, pumps and other appurtenant equipment shall be installed and maintained to prevent the loss of volatile fractions.
3. The owner/operator (o/o) shall log all shipments of oil to other parties and the hauler of said oil. Additionally, this log shall contain the mass (or volume) and the date of the oil shipment.

Fee Schedule: 5 (b)

Rating: 32000 gallons

SIC: 9711

SCC: N/A

Location/UTM(Km): 529E/3902N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

NTC - Public Works
Attn: Air Resources Manager

Fort Irwin, CA 92310

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

4.The o/o shall keep the log on-site for a minimum of two (2) years and provide it to District personnel on request.

5.This facility shall emit less than the following on a calendar year basis; Oxides of Nitrogen (NOx) - 25 tons, Volatile Organic Compound (VOC) - 25 tons, Particulate Matter less than 10 microns (PM10) - 15 tons, and Hazardous Air Pollutants (HAP) - 10 tons per year for any single HAP and 25 tons per year for any combination of HAPs. Compliance shall be demonstrated annually to the District through the submission of a District approved Comprehensive Emission Inventory Report (CEIR) or other District approved equivalent method. The report shall be submitted to the District evry calendar upon request.