



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

T008108

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: AUGUST 2002

OWNER OF OPERATOR (Co.#15)

Pacific Gas & Electric/Air Permits
PO Box 28150
Oakland, CA 94604-8150

EQUIPMENT LOCATION (Fac.#535)

PG&E - Hinkley Compressor Station
35863 Fairview Road
Hinkley, CA 92347

Description:

USED OIL TANK consisting of: 100 BBL, V-041, 10' dia. X 7' 2" I S/S.

CONDITIONS:

1. This tank is limited to storing IC engine waste oil generated on-site at Pacific Gas & Electric.
2. All flanges, seals, pumps and other appurtenant equipment shall be installed and maintained to prevent the loss of volatile fractions.
3. The owner/operator (o/o) shall log all shipments of oil to other parties and the hauler of said oil. Additionally, this log shall contain the mass (or volume) and the date of the oil shipment.
4. The o/o shall keep the log on-site for a minimum of two (2) years and provide it to District personnel on request.

Fee Schedule: 5 (a)

Rating: 4200 gallons

SIC: 4939

SCC: N/A

Location/UTM(Km):
485E/3862N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Pacific Gas & Electric/Air Permits
PO Box 28150
Oakland, CA 94604-8150

By: **COPY**
Brad Poiriez
Executive Director