



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

### PERMIT TO OPERATE

T009029

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

### EXPIRES LAST DAY OF: MARCH 2026

#### OWNER OF OPERATOR (Co. #2258)

Flyers Energy LLC  
2360 Lindbergh Street  
Auburn, CA 95602

#### EQUIPMENT LOCATION (Fac. #962)

Flyers #4402 Santa Fe Ave  
9269 Santa Fe Ave  
Hesperia, CA 92345

#### Description:

DIESEL TANKS consisting of:

#### EQUIPMENT

Capacity	Equipment Description
10	Diesel Storage Tank No. 3
20	Diesel Storage Tank No. 4
10	Diesel Storage Tank No. 5

#### CONDITIONS:

1. Each petroleum product tank must be equipped with a permanent submerged fill pipe. A person shall not transfer or permit the transfer of petroleum products into this tank by any means other than the permanent submerged fill pipe.

2. This equipment shall be operated in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.

Fee Schedule: 5 (b)

Rating: 40000 gallons

SIC: 5541

SCC: 40600651

Location/UTM(Km): 473E/3808N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Flyers Energy LLC  
2360 Lindbergh Street  
Auburn, CA 95602

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer

3.This equipment shall be operated and maintained in strict accord with the recommendations of its manufacturer or supplier and/or sound engineering principles.

4.The owner/operator, o/o, shall install, operate and maintain these tanks and their ancillary piping, valving, electrical and instrumentation consistent with those requirements to be compliant with District Rules 462 and 463.

5.The associated Gasoline Dispensing Facility is permitted under separate District permit G001963.