



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

T009501

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: SEPTEMBER 2011

OWNER OF OPERATOR (Co.#1200)

Federal Bureau of Prisons - Victorville
13289 Air Base Road
Victorville, CA 92394

EQUIPMENT LOCATION (Fac.#2082)

Federal Bureau of Prisons (FCI-I)
13777 Air Expressway Blvd
Victorville, CA 92394

Description:

DIESEL TANKS consisting of:

EQUIPMENT

Capacity	Equipment Description
20	One 20,000 gallon belowground diesel tank
20	One 20,000 gallon belowground diesel tank

CONDITIONS:

1. Each petroleum product tank must be equipped with a permanent submerged fill pipe. A person shall not transfer or permit the transfer of petroleum products into this tank by any means other than the permanent submerged fill pipe.
2. This equipment shall be operated in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
3. This equipment shall be operated and maintained in strict accord with the recommendations of its manufacturer or supplier and/or sound engineering principles.

Fee Schedule: 5 (b)

Rating: 40000 gallons

SIC: 9223

SCC: 40600651

Location/UTM(Km):
467E/3825N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Federal Bureau of Prisons - Victorville
PO Box 5400

Adelanto, CA 92301

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

4. The owner/operator, o/o, shall install, operate and maintain these tanks and their ancillary piping, valving, electrical and instrumentation consistent with those requirements to be compliant with District Rules 462 and 463.

5. The associated Gasoline Dispensing Facility is permitted under separate District permit N005339.