



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

AUTHORITY TO CONSTRUCT

T011372

If construction is not completed by the expiration date of this permit, it may be renewed for one additional year upon payment of applicable fees. Any additional extension will require the written approval of the Air Pollution Control Officer. This Authority to Construct may serve as a temporary Permit to Operate provided the APCO is given prior notice of intent to operate and the Permit to Operate is not specifically denied.

EXPIRES LAST DAY OF: NOVEMBER 2026

OWNER OF OPERATOR (Co.#1660)

Kern River Gas Transmission Co.
2755 E Cottonwood Parkway, Ste 300
Salt Lake City, UT 84121

EQUIPMENT LOCATION (Fac.#3323)

Kern River - Mountain Pass Meter Station
67750 Bailey Road
Mountain Pass, CA 92366

Description:

STORAGE TANK consisting of: Tidy Tanks Model DCS-4500; horizontal tank with dimensions of 145'L X 50" diameter; 925 gallon; painted beige and equipped with a vent valve and an emergency vent, one of each for the tank and the tank containment vessel; 4-total vents.

EQUIPMENT

Capacity	Equipment Description
2	Aboveground Storage Tank (2000 gallon capacity)

CONDITIONS:

1. The o/o shall construct, operate, and maintain this equipment in strict accord with the recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emission of contaminants practicable. [Rule 204]
2. The o/o shall log the dates of removal of liquids from this tank, and the volume removed in gallons. This log shall be maintained current for a minimum of two (2) years and provided to Federal, State, and District personnel on request. This log shall be either at the site or be readily available to District personnel. [Rule 204]

Fee Schedule: 5 (a)

Rating: 1000 gallons

SIC: 4922

SCC: 4079998

Location/UTM(Km):
633E/3926N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Kern River Gas Transmission Co.
2755 E Cottonwood Parkway, Ste 300
Salt Lake City, UT 84121

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

3. The o/o shall only store natural gas pipeline liquids in this tank. [Rule 204]

4. All flanges, seal pumps and other appurtenant equipment shall be maintained to prevent loss of volatile fractions. [Rule 204]

5. The owner/operator shall determine the stored materials Reid Vapor Pressure in accordance with ASTM Method D 323-82, when contents exceed 55 gallons, considered the minimum amount to retrieve a sample. This determination shall occur quarterly, and immediately after pigging operations; results shall be logged and maintained current for a minimum of two (2) years and provided to Federal, State, and District personnel on request. This log shall be either at the site or be readily available to District personnel. [Rule 204; 219]

6. The organic material stored in this tank shall not have a Reid Vapor Pressure exceeding 200 mm Hg (3.9 pounds per square inch), when tested pursuant to condition 5. In the event that the material stored exceeds this vapor pressure, the o/o shall contact the District immediately to discuss permitting of additional equipment to effect vapor recovery requirements pursuant to District Rules 461, and 463. [Rule 204; 461; 463]