



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

T012185

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: SEPTEMBER 2020

OWNER OF OPERATOR (Co.#133)

NASA/Goldstone
93 Goldstone Rd.
Fort Irwin, CA 92310

EQUIPMENT LOCATION (Fac.#611)

NASA/Goldstone Deep Space Communications Complex
Goldstone Lake
Fort Irwin, CA 92311

Description:

STORAGE TANK, WASTE OIL - MARS SITE consisting of: A 2,000 gallon, underground, double walled tank manufactured by Joor Manufacturing, serial G-81-3. This tank is electronically monitored by a Veeder Root 350 TLS monitoring system, and is used to store waste oil generated from the ten (10), diesel IC engines powering emergency generators at the Mars site. This tank includes a vent pipe measuring 25 feet high and 3 inches in diameter.

CONDITIONS:

1. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles in a manner consistent with good air pollution control practice for minimizing emissions. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

[District Rule 1302(C)(2)(a)]

2. The owner/operator shall strictly adhere to all Federal, State, and/or District rules and regulations which pertain to the storing, handling, transferring, transporting, and disposing of waste oils.

[District Rule 1302(C)(2)(a)]

3. Only waste oil generated from the ten (10), diesel IC engines powering emergency generators at the Mars site, under the following permits, shall be transferred and/or stored into/in this tank: E000272, E000273, E000274, E000275, E000276, E000277, E000278, E000279, E000280, and E000281.

[District Rule 463(D)(1)]

Fee Schedule: 5 (a)

Rating: 2000 gallons

SIC: 9661

SCC: 30630006

Location/UTM(Km):
517E/3906N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

NASA/Goldstone
93 Goldstone Rd.
Fort Irwin, CA 92310

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

4. All of the components of this tank, including but not limited to tanks, flanges, seals, pipes, pumps, valves, meters, connectors, shall be maintained and operated so as to prevent fugitive vapor leaks, fugitive liquid leaks, and excess organic liquid drainage during transfer, storage and handling operations. This condition shall be verified via a visual inspection conducted on a monthly basis.

[District Rule 463(C)(3)].

5. Facility-wide emissions shall not exceed 80 tons per year of NO_x, 24 tons per year of VOC, and 18 tons per year of PM₁₀. Facility-wide emissions shall be calculated and recorded, in tons, on a calendar month basis and totaled for each consecutive twelve-month basis. For emergency engines, only emissions generated during testing and maintenance shall apply toward the facility-wide emission limits. These records shall be maintained as current for a minimum of five (5) years, and made available upon District, State and/or Federal request.

[District Rule 221(B)]

6. The owner/operator shall maintain an operations log for this equipment, current and on-site (or at a central location) for a minimum of five (5) years, and this log shall be provided to District, State and/or Federal personnel, upon request. The log shall include, at a minimum, the information specified below:

a. Record of liquids stored in this tank, verified by recording the dates of each oil transfer to this tank from the allowed engines specified in condition 3, and by retention of the waste manifests issued upon disposal of waste oil.

b. A log containing the date and results of the inspections specified by condition 4, and any repairs and maintenance conducted on this equipment.

[District Rule 463 (D)(1) and (D)(3)].

7. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]