



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

AUTHORITY TO CONSTRUCT

T013049

If construction is not completed by the expiration date of this permit, it may be renewed for one additional year upon payment of applicable fees. Any additional extension will require the written approval of the Air Pollution Control Officer. This Authority to Construct may serve as a temporary Permit to Operate provided the APCO is given prior notice of intent to operate and the Permit to Operate is not specifically denied.

EXPIRES LAST DAY OF: FEBRUARY 2026

OWNER OF OPERATOR (Co. #460)

Sully-Miller Contracting, Co
135 State College Blvd Suite 400
Brea, CA 92821

EQUIPMENT LOCATION (Fac. #2933)

Sully-Miller Contracting Co- Air Expressway
15650 Air Expressway
Victorville, CA 92392

Description:

STORAGE TANKS, ASPHALT OIL consisting of: Hot asphalt oil storage equipped with one 1.5 MMBtu/hr Natural Gas fired heater.

EQUIPMENT

Capacity	Equipment Description
20	One 20,000 gallon hot asphalt oil storage tank
5	One 5,000 gallon hot asphalt oil storage tank

CONDITIONS:

1. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.

[District Rule 204]

2. This equipment shall be operated and maintained in strict accord with the recommendations of its manufacturer or supplier and/or sound engineering principles.

[District Rule 204]

3. This equipment shall only be used for storage of hot asphalt oil.

Fee Schedule: 5 (b)

Rating: 25000 gallons

SIC: 2951

SCC: 30500212

Location/UTM(Km): 470E/3825N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Sully-Miller Contracting, Co
135 State College Blvd, Suite 400
Brea, CA 92821

By: **COPY**

Brad Poiriez

Air Pollution Control Officer

[District Rule 1320]

4. Tank throughput is limited to 706,298 gallons/year.
[Rule 1303]

5. All of the components of this tank, including but not limited to tanks, flanges, seals, pipes, pumps, valves, meters, connectors, shall be maintained and operated so as to prevent fugitive vapor leaks, fugitive liquid leaks, and excess organic liquid drainage during transfer, storage and handling operations.
[District Rule 463(C)(3)]

6. The owner/operator shall maintain an operations log for this equipment, current and on-site (or at a central location) for a minimum of two (2) years, and this log shall be provided to District, State and/or Federal personnel, upon request. The log shall include, at a minimum, the information specified below:

- a. Record of liquids stored in this tank, verified by MSDS and by retention of the waste manifests issued upon disposal of waste oil.
- b. A log containing any repairs and maintenance conducted on this equipment.

[District Rule 463 (D)(1) and (D)(3)].

7. This equipment and associated operations shall not discharge an exhaust stream that exhibits opacity greater than twenty percent.
[District Rule 401]

8. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.
[District Rule 107(b); H&S Code 39607 & 44341-44342; and 40 CFR 51, Subpart A]