



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

AUTHORITY TO CONSTRUCT

T015079

If construction is not completed by the expiration date of this permit, it may be renewed for one additional year upon payment of applicable fees. Any additional extension will require the written approval of the Air Pollution Control Officer. This Authority to Construct may serve as a temporary Permit to Operate provided the APCO is given prior notice of intent to operate and the Permit to Operate is not specifically denied.

EXPIRES LAST DAY OF: JULY 2026

OWNER OF OPERATOR (Co. #2520)

Victorville, City of
14343 Civic Drive
Victorville, CA 92392

EQUIPMENT LOCATION (Fac. #4472)

City of Victorville - Natural Gas Distribution
19000 Perimeter Road
Victorville, CA 92394

Description:

ODORANT TANK AND INJECTION SYSTEM consisting of: Odorant injection system with 500 gallon above ground odorant tank and related equipment

CONDITIONS:

1. This equipment shall be installed, operated and maintained in good operating condition and in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.
[District Rule 402]

2. The odorant tank and the delivery truck used to fill the odorant tank must be equipped with a Two Point Phase I type vapor recovery system capable of achieving 95% control; this vapor recovery system must be utilized whenever the odorant tank is being filled.
[District Rules 402 and 1303]

3. This tank shall not be filled to greater than 90% of its maximum capacity (to allow for expansion within tank).
[District Rule 402]

4. A closed loop system shall be used and maintained to ensure that odorant discharged to the atmosphere is minimized during equipment servicing and maintenance.

Fee Schedule: 5 (a) Rating: 500 gallons SIC: 9131 SCC: 30600811 Location/UTM(Km): 466E/3828N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Victorville, City of
14343 Civic Drive
Victorville, CA 92392

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

[District Rule 402]

5. The owner/operator (o/o) shall maintain current and on-site for a minimum of five (5) years an operational/maintenance log. This log shall be provided to District, State or Federal personnel upon request and shall include, at a minimum, the following information (NOTE: The daily log information provides a basis for the Toxic Emission Inventory required by AB 2588.):

- a. Annual (calendar year total) quantity of odorant used (in gallons);
- b. Monthly equipment inspections and maintenance, including descriptions of any deficiencies and corrective action.

[District Rule 204]

6. A facility-wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b); H&S Code 39607 & 44341-44342; 17 CCR 93400 et seq.; and 40 CFR 51, Subpart A]