



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

A003276

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: FEBRUARY 2000

OWNER OF OPERATOR (Co.#100)

Metropolitan Water District of So Calif
158000 MWD Road
Parker Dam, CA 92267

EQUIPMENT LOCATION (Fac.#571)

MWD - Gene Pumping Plant
158000 MWD Road
Parker Dam, CA 92267

Description:

ABRASIVE BLASTING SYSTEM consisting of: Sanstorm Model HE-4N66, 100 lb capacity with a rating of 40 lb/hr.

CONDITIONS:

1. This abrasive blast system shall only use steel and/or iron shot and/or grit; and/or abrasives that have been certified by the California Air Resources Board for dry unconfined usage (Ref: California Code of Regulations, Title 17, Section 92520).
2. This abrasive blast system shall be operated/maintained in strict accord with manufacturer's/supplier's recommendation and/or sound engineering principles.
3. The total amount of abrasive material used at this facility shall not exceed 20 tons/year and a log shall be maintained showing the amount of abrasive material purchased.

Fee Schedule: 7 (e)

Rating: 1 device

SIC: 4941

SCC: 99999999

Location/UTM(Km): 761E/3798N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Metropolitan Water District of So Calif
P O Box 54153

Los Angeles, CA 90054

By: **COPY**

Brad Poiriez

Air Pollution Control Officer