



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B000795

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: FEBRUARY 2014

OWNER OF OPERATOR (Co.#866)

Southern California Logistics Airport
18374 Phantom
Victorville, CA 92394

EQUIPMENT LOCATION (Fac.#1612)

SCLA - Phantom
18374 Phantom
Victorville, CA 92394

Description:

BOILER consisting of: Kewanee Model H-M235-KGO, S.N. R.O.608, 2.937 MMBTU/hr, natural gas fired hot water boiler (fuel oil backup), located in building 686.

CONDITIONS:

1. The owner/operator (o/o) shall operate this equipment in strict accord with the manufacturer's specifications and/or sound engineering principles.
2. The o/o shall maintain a record of fuel oil used to fire this boiler and submit it to the District on request. The record shall be retained for a minimum period of two years.

Fee Schedule: 2 (c)

Rating: 2940000 Btu

SIC: 4581

SCC: 10300603

Location/UTM(Km):
466E/3827N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Southern California Logistics Airport
18374 Phantom
Victorville, CA 92394

By: **COPY**
Eldon Heaston
Air Pollution Control Officer