



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B001691

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: SEPTEMBER 2000

OWNER OF OPERATOR (Co.#257)

All American Pipeline, LP
10000 Ming Avenue
Bakersfield, CA 93311

EQUIPMENT LOCATION (Fac.#917)

Cadiz Pump Station
6 Miles So of Route 66
Cadiz, CA 92319

Description:

INTERNAL COMBUSTION ENGINE consisting of: a Caterpillar engine, model 3306, engine number 809, serial number 07Y02125 which is natural gas fired and rated at 195 bhp. This engine drives a circulating pump and is provided with a catalytic converter.

CONDITIONS:

1. The o/o shall only operate one of the circulating pumps delineated on District permits B001691 and B001692 at any time. However, both may be operated for a period of no more than 30 minutes to allow switching from one unit to another.
2. The maximum emission rate for oxides of nitrogen shall be 2.0 grams/hp-h at 15% oxygen, during normal operation. The mass emission rate of oxides of nitrogen, in lb/h shall be reported in the annual tests mentioned below.
3. The o/o shall operate and maintain this unit in strict accord with the District's New Source Review date May 20, 1994.
4. Annual compliance emissions tests shall be conducted each October (having been conducted initially in October 1997) on at least one engine that has been operated in the prior 90 days. Compliance testing shall follow those procedures in a District approved protocol, submitted following the administrative/testing methods in the District's "Compliance Testing Procedural Manual". Test results shall include the bhp at which the engine was tested and be submitted to the District no later that 45 days subsequent to the last day of on-site sample collections and/or measurements.
5. The owner/operator (o/o) shall maintain the weekly volume of natural gas burned and the hours of operation, compiled on a monthly basis. Such records shall be kept at the Barstow Office and provided to the District upon request.

Fee Schedule: 1 (b)

Rating: 195 bhp

SIC: 4612

SCC: 9999999

Location/UTM(Km):
640E/3817N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

All American Pipeline, LP
PO Box 40160
Bakersfield, CA 93384-0160

By: **COPY**
Eldon Heaston
Air Pollution Control Officer