



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B002122

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: DECEMBER 2016

OWNER OF OPERATOR (Co.#500)

ACE Cogeneration Company
12801 S Mariposa Street
Trona, CA 93562

EQUIPMENT LOCATION (Fac.#1051)

ACE Cogeneration Company
12801 S Mariposa Street
Trona, CA 93562

Description:

COOLING TOWER consisting of: a Hamon Model No. CF 4248 four cell wooden cooling tower with 12,000 square feet of cooling area and appurtenant water system. Insp #: 2898

EQUIPMENT

Capacity	Equipment Description
800	Four Draft Fans (200 hp each)
2100	Three Circulating Water Pumps - 33,000 gpm each (700 hp each)
200	Two Cooling Water Pumps - 2300 gpm (100 hp each)
5	Pump, Auxiliary cooling water 300 gpm (5 hp)

CONDITIONS:

1. All equipment shall be maintained and operated in strict accord with recommendations of the manufacturer/supplier and/or sound engineering principles.

[Rule 1302(C)(2)(a), Version in SIP = CARB Ex. Order G-73, 40 CFR 52.220(c)(239)(i)(A)(1) 61 FR 58133; Current Rule Version = 08/26/06]

2. The owner/operator shall not operate this cooling tower unless the concentration of hexavalent chromium in the circulating water does not exceed 0.15 milligram per liter (mg/L). The water shall be tested every six months in accordance with American Public Health Method 312B. Records of this testing shall be retained for five years and made available, to District, State or Federal personnel upon request. Records shall contain at a minimum the date, results of the hexavalent chromium analysis, and the name of the company who performed the test. The owner/operator shall maintain records of all cooling towers in one location, with current originals or copies at

Fee Schedule: 1 (d) Rating: 3105bhp SIC: 4911 SCC: 99999999 Location/UTM(Km): 465E/3958N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

ACE Cogeneration Company
12801 S Mariposa Street
Trona, CA 93562

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

this facility site. [Rule 204]

3.The drift rate shall not exceed 0.0015 percent with a maximum circulation rate of 64,000 GPM. The maximum PM and PM10 emission rates shall not exceed 15 and 13 lb/hr respectively.

[MDAQMD Rule 1303(A) BACT; SIP Version 3/25/1996; 40 CFR 52.220(c)(239)(i)(A)(1); Current Rule Version = 09/24/01]

4.Weekly tests of the blowdown water quality shall be performed by o/o in accordance with the standard test procedures. These weekly recordings, including mass emission rate, are to be placed into a log and be maintained on sites for a minimum of five (5) years and be provided to District, state or federal personnel on request.

[MDAQMD Rule 1303(A) BACT; SIP Version 3/25/1996; 40 CFR 52.220(c)(239)(i)(A)(1); Current Rule Version = 09/24/01]

5.This equipment does not require a regularly scheduled emission compliance test. However, emission compliance testing may be required at the discretion of the District.

[MDAQMD Rule 204 - Permit Conditions; Version in SIP = CARB Ex. Order G-73, 40 CFR 52.220(c)(39)(ii)(B) - 11/09/78 43 FR 52237; Current Rule Version = 07/25/77]

6.A maintenance procedure shall be established that states how often and what procedures will be used to ensure the integrity of the drift eliminators. This procedure is to be kept on-site and be available to District, state or federal personnel on request.

[MDAQMD Rule 204 - Permit Conditions; Version in SIP = CARB Ex. Order G-73, 40 CFR 52.220(c)(39)(ii)(B) - 11/09/78 43 FR 52237; Current Rule Version = 07/25/77]