

MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park AvenueVictorville, CA92392-2310 760.245.1661 -- 800.635.4617 -- FAX760.245.2022

INACTIVE

B003052

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: JANUARY 2021

OWNER OF OPERATOR (Co.#2733)

NextEra Energy Capital Holdings, Inc. 700 Universe Blvd. Juno Beach,FL33408

EQUIPMENT LOCATION (Fac. #941)

Resurgence Solar & BESS 41100 Highway 395 Boron,CA93516

Description:

HTF ULLAGE SYSTEM consisting of:System 9 at SEGS IV, with three units.

EQUIPMENT

Capacity	Equipment Description
7.5	Ullage Vessel Pump P-116, 300 gpm @ 160 psi
0	Ullage Condenser E-100, 180 psi @ 735 deg F (110.42 MMBtu/hr)
0	Ullage Vessel V-101, 125 psi @ 650 deg F (575 gal)

CONDITIONS:

- 1. This equipment shall be operated and maintained in strict accord with the manufacturer's and/or supplier's recommendations and/or sound engineering principles.
- 2.If current non-criteria substances become regulated as toxic or hazardous substances and are used in this equipment, the owner/operator (o/o) shall submit to the District a plan demonstrating how compliance will be achieved and maintained with such regulations.

Fee Schedule:7 (i)

Rating:1device

SIC:4911

SCC:99999999

Location/UTM(Km):450E/3874N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

NextEra Energy Capital Holdings, Inc. 700 Universe Blvd. Juno Beach,FL33408

By: COPY
Brad Poiriez
Air Pollution Control Officer