



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B003937

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: FEBRUARY 2004

OWNER OF OPERATOR (Co.#100)

Metropolitan Water District of So Calif
158000 MWD Road
Parker Dam, CA 92267

EQUIPMENT LOCATION (Fac.#774)

MWD - Iron Mountain Pumping Plant
6001 Iron Mt Pumping Road
Earp, CA 92242

Description:

IC ENGINE, PORTABLE GENERATOR consisting of:

One Waukesha, Diesel fired internal combustion engine Model No. F-817G and Serial No. 243280, producing 175 bhp with 6 cylinders at 1800 rpm while consuming a maximum of 10.0 gal/hr. This equipment powers a Generator Model No. and Serial No., rated at.

CONDITIONS:

1. This equipment shall only be operated/maintained in strict accord with manufacturer's or supplier's recommendations and/or sound engineering principles.
2. An operator's log shall be maintained which, as a minimum, contains the date, time and hours the engine was operated.
3. The o/o shall maintain these logs on-site for a minimum two (2) years and provide them to District personnel on request.
4. The o/o shall comply with all applicable Rules and Regulations of the District.

Fee Schedule: 1 (b)

Rating: 175 bhp

SIC: 4941

SCC: 20100102

Location/UTM(Km): 673E/3780N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Metropolitan Water District of So Calif
P O Box 54153

Los Angeles, CA 90054

By: **COPY**

Brad Poiriez

Air Pollution Control Officer