



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
 760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B003990

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: NOVEMBER 2004

OWNER OF OPERATOR (Co.#84)

NTC - Public Works
 Bldg 602, 5th Street
 Fort Irwin, CA 92310

EQUIPMENT LOCATION (Fac.#589)

NTC Training Mission
 Bldg. 602, 5th street
 Fort Irwin, CA 923105085

Description:

PORTABLE ROCK CRUSHING PLANT MOUNTED ON TWO TRAILERS LOCATED ON BARSTOW ROAD UTM 055375 consisting of:

EQUIPMENT

Capacity	Equipment Description
0	Trailer #1
0	Feed Hopper
0	Screen, Single Deck
125	Internal Combustion Engine, Diesel Fueled
0	Trailer #2
0	Conveyor Belt
0	Crusher, Jaw
125	Internal Combustion Engine, Diesel Fueled
0	Conveyor Belt
0	TOTAL HORSEPOWER

CONDITIONS:

Fee Schedule: 1 (c)

Rating: 250 bhp

SIC: 9711

SCC: 9999999

Location/UTM(Km):
 529E/3902N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

NTC - Public Works
 Attn: Air Resources Manager
 Fort Irwin, CA 92310

By: **COPY**
 Brad Poiriez
 Executive Director

1. Material handled shall contain sufficient natural or added moisture to ensure compliance with District Rules 401, 402, and 403. Sufficient water and equipment to properly wet the material being processed or handled shall be maintained in operable condition on-site.
2. The process weight shall not exceed 75 tons per hour.
3. These Internal Combustion (I.C.) Engines shall only burn diesel fuel or JP-8.
4. The fuels used to operate these I.C. Engines shall not contain sulfur in excess of 0.05% by weight.
5. The owner/operator (o/o) shall require from their supplier analytical results relating to the sulfur content of the fuel delivered and shall not accept delivery whenever the sulfur concentration exceeds 0.05% by weight.