



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B004276

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: NOVEMBER 1998

OWNER OF OPERATOR (Co.#69)

Southern California Edison
P.O. Box 5085
Rosemead, CA 91770

EQUIPMENT LOCATION (Fac.#1525)

SCE - AVAQMD - Var Locations/inactive
District Wide
MDAQMD, CA 92392

Description:

GENERATOR - ICE DRIVEN consisting of: a Cummins, model NTA 85561, 6 cylinder engine. This engine is turbo-charged, aftercooled and considered by this District to represent BACT for this type of engine in this type of operation. The engine usually is run at 1800 rpm, fires diesel fuel at a maximum of 21.3 gal/h and is rated at 465 bhp.

One , fired internal combustion engine Model No. and Serial No. , producing bhp with cylinders at rpm while consuming a maximum of . This equipment powers a Model No. and Serial No. , rated at .

CONDITIONS:

1. The owner/operator, o/o, shall log the starting and stopping times of the all operational periods of this generator, to the nearest hour, the date and the fuel consumption in gallons.
2. The o/o shall use only diesel fuel whose sulfur concentration is less than or equal to 0.05% by weight.
3. The o/o shall log all purchases of diesel fuel including the volume (or weight), date received and the sulfur content. The o/o may use the supplier's furnished certification of sulfur content if the certifications are maintained on file as a part of the log.
4. The logs shall be kept current, on-site for a minimum of 2 years and provided to District personnel on request.

Fee Schedule: 1 (c)

Rating: 465 bhp

SIC: 4911

SCC: 99999999

Location/UTM(Km):
473E/3956N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Southern California Edison
P.O. Box 5085

Rosemead, CA 91770

By: **COPY**
Brad Poiriez
Executive Director

5. The o/o is limited to operating this generator to provide power to customers when the o/o must repair, replace, up-grade, change or otherwise curtail power normally provided by the o/o.

6. This unit shall not be operated more than 4140 h/year with the prior written approval of the District APCO.