



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B004307

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: SEPTEMBER 2000

OWNER OF OPERATOR (Co. #1732)

Helendale Community Services District
26540 Vista Road Suite B
Helendale, CA 92342

EQUIPMENT LOCATION (Fac. #1418)

Helendale Community Services District
28685 Helendale Road
Helendale, CA 92342

Description:

WASTEWATER-CHLORINE TREATMENT consisting of: Chlorine Contact System whose volume is approximately 94,000 gallon, and is driven by a sample pump motor of 1.0 hp.

CONDITIONS:

1. This facility shall not treat more than 1.2 millions gallons of waste water per day.
2. The owner/operator, o/o, shall log the daily volume of wastewater received and treated. The log shall be maintained current, on-site for a minimum of 2 years and provided to District personnel on request.
3. The o/o shall comply with all Rules and Regulations of this District. Applicable rules include, but are not limited to Regulation IV.
4. The o/o shall operate and maintain this equipment in strict accord with those recommendations of the manufacturer and/or federal, State, regional and local waste water discharge permits.

Fee Schedule: 1 (a) Rating: 1bhp SIC: 4952 SCC: 99999999 Location/UTM(Km): 470E/3848N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Helendale Community Services District
P.O. Box 359
Helendale, CA 92342-0359

By: **COPY**
Brad Poiriez
Air Pollution Control Officer