



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B004706

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: JULY 1998

OWNER OF OPERATOR (Co.#600)

Oldcastle APG West, Inc
4150 W Turney
Phoenix, AZ 85019

EQUIPMENT LOCATION (Fac.#189)

Oldcastle APG West/dba Superlite Block
No. 1 Ice Plant Road
Needles, CA 92363

Description:

ELECTRICAL GENERATOR consisting of: Electrical generator drives the Crushing/Screening Operations described inb District permit No. B004705. This generator is described as a Caterpillar model 3412TA whose serial No. is 81Z3642. This engine is rted at 400 kW(e) which is equivalent to 536 bhp. It is diesel fueled, has 12 cylinders and runs a 1800 rpm. It is also direct injected, turbocharged aftercooled and has its ingition retarded to lower emissions.

CONDITIONS:

1. This equipment shall not operate more than 12 hours in any one day, from midnight to midnight.
2. This equipment shall use no other fuel but diesel without the prior written approval of the APCO.
3. The sulfur content of the fuel used in this equipment shall not exceed 0.05% on a mass basis. The owner/operator (o/o) shall log the volume or mass and the dates of all purchases of fuel and the sulfur content. The o/o may use the supplier's sulfur analytical data, but at the discretion of the District, shall take a sample of the fuel and submit it for analysis by ASTM method D-2622 or D-4294 as they may be amended from time to time. An independent laboratory shall conduct the anlayses. The results of said analyses shall be logged and forwarded to the District on receipt.
4. The o/o shall comply with all applicable rules and regulations of this District.
5. The o/o shall maintain a daily log of the total hours of operation and the date. The log shall be maintained current, on-site, for a minimum of two years and provided to District personnel on request. This log may be the same one specified in No. 3 above.

Fee Schedule: 7 (c)	Rating: 536 device	SIC: 3273	SCC: 99999999	Location/UTM(Km): 719E/3858N
---------------------	--------------------	-----------	---------------	---------------------------------

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Oldcastle APG West, Inc
4150 W Turney
Phoenix, AZ 85019

By: **COPY**
Eldon Heaston
Air Pollution Control Officer