MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT
14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

B004762

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: DECEMBER 2026

OWNER OF OPERATOR (Co.#3254)

5E SVM Operations, LLC
13200 Main Street
Trona, CA 93562

EQUIPMENT LOCATION (Fac.#2)

SVM - Trona Plant
13200 Main Street
Trona, CA 93562

Description:
CONVEYOR, TRANSLOADING consisting of: Wilson Mfg. And Design, Model 219, SN 9961122-131; design loading rate: 85 tons/hr.

EQUIPMENT

Capacity	Equipment Description
1	Motor, Exhaust Fan
10	Motor, Conveyor
10	Motor, Hydraulic Unit
0	Baghouse; DCE Vokes, Model 100, w/ A/C ratio 6.5 : 1.

CONDITIONS:

1. The owner/operator shall operate and maintain this dust collector in strict accord with those recommendations of the manufacturer/supplier and sound engineering principles.
[District Rule 204]

Fee Schedule: 1 (a) | Rating: 21 bhp | SIC: 1474 | SCC: 30107002 | Location/UTM(Km): 466E/3957N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

5E SVM Operations, LLC
P.O. Box 367
Trona, CA 93592-0367

By: **COPY**
Brad Poiriez
Executive Director

UNOFFICIAL

2. The owner/operator shall install and maintain instruments which allow measurements of the pressure differential across the bags. The o/o shall only operate this equipment when the pressure differential is in the range specified by the manufacturer/supplier.
[District Rule 204]

3. The owner/operator shall maintain an inventory of replacement bags on-site at all times which will ensure compliance with applicable Rules of District Regulation IV.
[District Regulation IV]

4. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit was issued unless noted otherwise.
[District Rule 204]

5. The owner/operator shall not operate this equipment in violation of District Rules 401, 402, and 403 nor any time the baghouse is nonoperational.
[District Rules 401, 402, and 403]