



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

B004792

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: NOVEMBER 2004**

### **OWNER OF OPERATOR (Co.#86)**

MAGTFTC MCAGCC  
Box 788110, Bldg 1418  
Twentynine Palms, CA 92278-8110

### **EQUIPMENT LOCATION (Fac.#591)**

USMC AGCC  
Box 788110, Bldg. 1451  
Twentynine Palms, CA 92278-8110

#### **Description:**

IC ENGINE, ELECTRICITY GENERATOR (BLDG 9000, RANGE 500) consisting of: a Cummins, diesel fired, model NT855G6, serial number 1141755, ICE. The engine, which is rated at 435 bhp and burns a maximum of 25 gal/h, drives an electrical generator by DMT Company, their model DMT-280CA, serial number 88419A1. The generator is rated at 250 kW(e). Note: This unit powers the movement of targets.

#### **CONDITIONS:**

1. Operation and maintenance of this equipment shall be conducted in compliance with the recommendation of the manufacturers and the data/specifications submitted with the application under which this permit has been issued, unless specifically exempted hereunder. The submittal is an integral part of this permit and acts as specific limitations on this equipment.
2. The o/o shall use only diesel fuel or biodiesel B20 fuel whose sulfur concentration is less than or equal to 0.05% by weight or JP-8 fuel.
3. The owner/operator, o/o, shall log, at a minimum the following:
  - a. The starting and stopping times, to the nearest one-quarter hour, of all operational periods;
  - b. The delivery dates of fuel;
  - c. The volume (or weight) of fuel deliveries; and
  - d. The supplier's certification of the sulfur concentration of the fuel.This log shall be maintained current, on-site for a minimum of 2 years and provided to District personnel on request.

Fee Schedule: 1 (c)

Rating: 435bhp

SIC: 9711

SCC: 99999999

Location/UTM(Km): 587E/3788N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

MAGTFTC MCAGCC  
Box 788110, Building 1418  
  
Twentynine Palms, CA 92278-8110

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer