



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B008871

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: APRIL 2006

OWNER OF OPERATOR (Co.#1509)

Nursery Products, LLC
P.O. Box 1439
Helendale, CA 92342

EQUIPMENT LOCATION (Fac.#2571)

Nursery Products, LLC
14479 Cougar Road
Helendale, CA 92342

Description:

IC ENGINE, GENERATOR consisting of:

One Caterpillar, Diesel fired internal combustion engine Model No. 3306B and Serial No. 8JJ00743, Direct Injected, Turbo Charged, producing 316 bhp with 6 cylinders at 1800 rpm while consuming a maximum of 15.0 gal/hr. This equipment powers a Generator Model No. and Serial No. , rated at .

EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	0.4	gm/bhp-hr
NOx	4.96	gm/bhp-hr
PM10	0.1	gm/bhp-hr
SOx	0.16	gm/bhp-hr
VOC	0.16	gm/bhp-hr

CONDITIONS:

1. Operation of this equipment shall be conducted in accordance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
2. The sulfur concentrations of all diesel fuel used for permitted equipment shall not exceed 0.05% on a weight basis.

Fee Schedule: 1 (c)

Rating: 316 bhp

SIC: 4953

SCC: 20100102

Location/UTM(Km):
459E/3826N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Nursery Products, LLC
P.O. Box 1439
Helendale, CA 92342

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

3. An operations log shall be maintained on-site for at least two years and be made available to District personnel on request. This log shall contain, as a minimum, the "Hour Meter" reading at the beginning and end of each day, and the total hours operated each day.
4. The applicant shall be required to comply with all applicable Rules and Regulations of the District.
5. This I.C. engine equipment shall only be operated/maintained in strict accord with manufacturer's/supplier's recommendations and/or sound engineering principles.
6. This Engine shall not be operated more than 7.5 hours in any single day.