



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B009188

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: JUNE 2014

OWNER OF OPERATOR (Co.#1047)

High Desert Power Project, LLC
19000 Perimeter Road
Victorville, CA 92394

EQUIPMENT LOCATION (Fac.#1849)

High Desert Power Project
19000 Perimeter Road
Victorville, CA 92394

Description:

DIESEL IC ENGINE, PORTABLE, LOW-USE, WATER PUMP consisting of: Year of MFG 2003

One Perkins, Diesel fired internal combustion engine Model No. 1004-42 and Serial No. AR36677, Direct Injected, producing 85.5 bhp with 4 cylinders at 2400 rpm while consuming a maximum of 4.0 lbs/hr. This equipment powers a NULL Pump Model No. NULL and Serial No. NULL, rated at 60 kW.

EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	0.899	gm/bhp-hr
NOx	5.818	gm/bhp-hr
PM10	0.296	gm/bhp-hr
SOx	0.03	lbs/hr
VOC	0.175	gm/bhp-hr

CONDITIONS:

1. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles in a manner consistent with good air pollution control practice for minimizing emissions. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

[District Rule 1302 (C)(2)(a)]

Fee Schedule: 1 (b)

Rating: 85.5 bhp

SIC: 4911

SCC: 20200102

Location/UTM(Km):
473E/3820N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

High Desert Power Project, LLC
ATTN: Accounts Payable

Victorville, CA 92394

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

2. This diesel ICE and its associated equipment cannot be operated at the same engine-print (spot) for more than 365 consecutive days. (This system must be moved within this facility or moved to another facility annually.)

[Title 17 CCR 93116.2(a)(29)]

3. This unit shall only be fired on ultra-low sulfur diesel fuel whose sulfur concentration is less than or equal to 0.0015% (15 ppm) on a weight per weight basis per CARB Diesel or equivalent requirements; or alternative diesel fuel, or CARB diesel fuel utilizing fuel additives, that has been verified through the Verification Procedure for In-Use Strategies to Control Emissions from Diesel Engines.

[Title 17 CCR 93116.3(a)]

4. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time by January 1, 2012.

[Title 17 CCR 93116.4(c)(2)(A)]

5. This engine has been designated as "low-use" pursuant to Title 17 CCR 93116. Engine operation shall not exceed 80 hours per year, except for in an emergency event as defined in Title 17 CCR 93116.

[Title 17 CCR 93116.2(a)(22) and 9.3116.3(c)(4)]

6. The owner/operator shall maintain an operations log for this unit, current and on-site (or at a central location), for a minimum of five (5) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:

- a. Date of each use and duration of each use (in hours);
- b. Reason for use (regular prime use, emergency, testing & maintenance, etc.);
- c. Calendar year operation in terms of fuel consumption (in gallons) and total hours; and,
- d. Fuel sulfur concentration (may use the supplier's certification of sulfur content if it is maintained as part of this log).

[Title 17 CCR 93116.4(c)(2)(C)]

7. This certified, low-use engine shall satisfy one of the following requirements by January 1, 2020:

- a. The portable diesel-fueled engine is certified to Tier 4 emission standards for newly manufactured nonroad engines; or,
- b. The portable diesel-fueled engine is equipped with a properly functioning level-3 verified technology; or,
- c. The portable diesel-fueled engine is equipped with a combination of verified emission control strategies that have been verified together to achieve at least 85% reduction in diesel PM emissions.

[Title 17 CCR 93116.3(b)(3)]

8. The owner/operator of this unit must submit a Statement of Compliance signed by the Responsible Official that the fleet standards are being achieved and a summary that identifies each portable engine in the fleet and the associated emission rate (g/bhp-hr) and other required information, see Title 17 CCR 93116.4(e)(2), (3), (4), (5), (6) and (7).

Compliance Dates Pursuant to 17 CCR 93116.4(e)(2):

Weighted DPM Emission Fleet Average Dates: January 1, 2013; January 1, 2017; and January 1, 2020.

Submit Statement of Compliance reports for the above Fleet Averages by: March 1, 2013; March 1, 2017; and March 1, 2020, respectively.

9. The owner/operator of fleets that are exempted from the requirements of section 93116.4 pursuant to section 93116.4 (a), the Responsible Official shall certify that all portable diesel-fueled engines in the fleet satisfy the requirements of section 93116.4(a). See Title 17 CCR 93116.4(f) for details.