



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B009647

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: MAY 2018

OWNER OF OPERATOR (Co.#457)

Victor Valley Community College District
18422 Bear Valley Road
Victorville, CA 92392

EQUIPMENT LOCATION (Fac.#1127)

Victor Valley Community College District
18422 Bear Valley Road
Victorville, CA 92392

Description:

BOILER consisting of: One (1) Bryan Flexible Tube Hot Water Boiler, Model # RV550-W-FDG-WLX, Serial # 77369, Rated at 5.5 MM Btu/hr, Low NOx burner model # UBX3G-50-RM7840L-M30-IRI

CONDITIONS:

1. Not later than 180 days after initial startup, the operator shall perform an initial compliance test on this equipment in accordance with the District Compliance Test Procedural Manual. This test shall demonstrate that this equipment does not exceed 30 ppmvd NOx as NO2 at 3% oxygen at its maximum natural gas firing rate.
2. Prior to the expiration date each year (beginning in 2007), the o/o shall either perform a NOx and CO compliance test, or have this equipment tuned, as specified by Rule 1157. A tune-up may be performed in lieu of a compliance test during those permit years when the annual heat input to this unit does not exceed 50,000 MMBtu per year.
3. This boiler shall use only natural gas as fuel and shall be equipped with a meter measuring fuel consumption in standard cubic feet.
4. The operator shall maintain a log for this equipment, which, at a minimum, contains the information specified below. This log shall be maintained current and on-site for a minimum of two (2) years and shall be provided to District personnel on request:
 - a. Cumulative annual fuel use in cubic feet;
 - b. Annual compliance test or tune-up verification; and,

Fee Schedule: 2 (d)

Rating: 5500000 Btu

SIC: 8221

SCC: 10300603

Location/UTM(Km):
473E/3820N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Victor Valley Community College District
18422 Bear Valley Road

Victorville, CA 92392

By: **COPY**
Brad Poiriez
Executive Director

c. Any repairs or modifications to the burner system

5. The owner/operator (o/o) shall operate this equipment in strict accord with the recommendations of the manufacturer or supplier and/or sound engineering principles and consistent with all information submitted with the application for this permit which produce the minimum emission of air contaminants.