



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA92392-2310  
760.245.1661 -- 800.635.4617 -- FAX760.245.2022

**INACTIVE**

B009754

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: NOVEMBER 2017**

### **OWNER OF OPERATOR (Co.#86)**

MAGTFTC MCAGCC  
Box 788110, Bldg 1418  
Twentynine Palms, CA92278-8110

### **EQUIPMENT LOCATION (Fac.#3247)**

USMC AGCC - USMC Facilities  
Box 788110, Bldg. 1451  
Twentynine Palms, CA92278

#### **Description:**

BOILER (BLDG 1934) consisting of: Rite Engineering Boiler Model 350 WG equipped a Power Flame Low NOX burner Model LNIC3-G-20 and accessory equipment. Boiler has a 3 MMBTU/hr heat input and 2.4 MMBTU/hr heat output.

#### **CONDITIONS:**

1. The owner/operator (o/o) shall operate this equipment in strict accord with the recommendations of the manufacturer or supplier and/or sound engineering principles and consistent with all information submitted with the application for this permit which produces the minimum emission of air contaminants.
2. This boiler shall use only natural gas as fuel and shall be equipped with a meter measuring consumption in standard cubic.
3. The o/o shall maintain a current, on-site (at a central location if necessary) log for this equipment for two (2) years, which shall be provided to District, State or Federal personnel upon request. This log shall include calendar year fuel use for this equipment in standard cubic feet, or Btu s.
4. This facility shall comply with District Rule 222-Limitations on Potential to Emit. Compliance with this rule will be demonstrated to the District on an annual basis through the submission of an approved Comprehensive Emission Inventory Report (CEIR). A copy of the most recent CEIR shall be maintained on-site and presented to District personnel upon request.

Fee Schedule: 2 (c)

Rating: 3000000Btu

SIC: 9711

SCC: 10300603

Location/UTM(Km): 587E/3788N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

MAGTFTC MCAGCC  
Box 788110, Building 1418  
Twentynine Palms, CA92278-8110

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer