



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

B010315

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: APRIL 2009**

**OWNER OF OPERATOR (Co.#46)**

Victorville, City of  
14343 Civic Drive  
Victorville, CA 92392-2399

**EQUIPMENT LOCATION (Fac.#2948)**

Victorville 2 Hybrid Power Project  
Perimeter Road  
Victorville, CA 92392

**Description:**

HRSG DUCT BURNER (HRSG 2) consisting of: Natural gas burner located with the heat recovery steam generator covered by B010314, maximum heat output of 424.3 MMBtu/hr.

**EQUIPMENT**

Capacity	Equipment Description
424.3	Duct Burner (max heat input 424.3 MMBtu/hr)

**CONDITIONS:**

1. Operation of this equipment shall be conducted in accordance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
2. This equipment shall be exclusively fueled with natural gas and shall be operated and maintained in strict accord with the recommendations of the manufacturer/supplier and/or sound engineering principles.
3. This duct burner shall not be operated unless the combustion turbine generator with valid District permit B010314, oxidation catalyst with valid District permit C010316, and selective catalytic reduction system with valid District permit C010317 are in operation.

Fee Schedule: 2 (f)

Rating: 424300000 Btu

SIC: 4911

SCC: 20100201

Location/UTM(Km):  
467E/3828N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Victorville, City of  
Public Works - Fleet Division  
  
Victorville, CA 92392-2399

By: **COPY**  
**Brad Poiriez**  
Executive Director

4. This equipment shall not be operated for more than 2000 hours per rolling twelve month period.

5. Monthly hours of operation for this equipment shall be recorded and maintained on site for a minimum of five (5) years and shall be provided to District personnel on request.