



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

B010726

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: SEPTEMBER 2025

OWNER OF OPERATOR (Co.#1531)

Mars Petcare US Inc.
2013 Ovation Parkway
Franklin, TN 37067

EQUIPMENT LOCATION (Fac.#2600)

Mars Petcare
13243 Nutro Way
Victorville, CA 92392

Description:

BOILER, NATURAL GAS (#1) consisting of: Cleaver-Brooks Model CB-700-350-150ST, Serial Number T1387-1-1 with a maximum heat input of 15,001 MMBtu/hr, equipped with a Low NOX Burner and Flue Gas Recirculation with a maximum natural gas fuel usage rate of 14,287 cubic feet per hour.

CONDITIONS:

1. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.
[District Rule 1302]

2. The operator shall maintain a log for this equipment, which, at a minimum, contains the information specified below. This log shall be maintained current and on-site for a minimum of two (2) years and shall be provided to District personnel on request:
a. Cumulative annual fuel use in cubic feet or operation in hours; and,
b. Annual tune-up verification.
[District Rule 1302]

3. Prior to the expiration date each year (beginning in 2010), the owner/operator shall have this equipment tuned, as specified by Rule 1157(I), Tuning Procedure.
[District Rule 1302]

Fee Schedule: 2 (e)

Rating: 15000000 Btu

SIC: 2047

SCC: 10300602

Location/UTM(Km): 474E/3817N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Mars Petcare US Inc.
Attention: Gregg Elmore

Victorville, CA 92392

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

4.This boiler shall only be fueled with utility grade natural gas.
[District Rules 1157 and 1302]

5.This boiler is subject to Rule 1157 RACT Standards as it is a new boiler and qualifies as a high annual heat input unit as defined in Rule 1157(B)(h); a permit unit with an annual heat input greater than or equal to 50,000 million Btu (MMBtu); BACT requirements for NOx are also required, therefore; this unit shall not emit:

- (a) Carbon Monoxide in excess of 100 ppmv @3% Oxygen; and
 - (b) NOx in excess of 9 ppmv, and/or 0.0109 lbs/MMBtu of heat input @3% Oxygen.
- [District Rule 1157]

6.Emission Compliance Testing, frequency:

This permit unit shall demonstrate compliance through emission compliance testing not less than once every 12 months, unless this unit was not operated during the previous 12 months; compliance testing shall occur no later than 90 days after start up following any periods of curtailed operations. The facility shall maintain records of operation regarding Boiler usage; including the operation of any rental units. These records shall be kept for no less than five years and made available to District personnel upon request.[District Rule 1157]

7.Emission Compliance Testing (Rule 1157(E)(1)(b)), Procedures:

- (i) Compliance testing shall follow the administrative procedures outlined in the District's Compliance Test Procedural Manual. All emission determinations shall be made as stipulated in the test protocol accepted by the District.
 - (ii) Emission determinations shall include, at a minimum, one emission compliance test conducted at 90% of the maximum firing rate allowed by the District permit or at normal operating conditions as determined and approved by the APCO.
 - (iii) No compliance determination shall be established based on data obtained from compliance testing, including integrated sampling methods, during a start-up period or shut-down period.
 - (iv) All ppmv emission limits specified shall be referenced at dry stack-gas conditions and 3.0 percent by volume stack-gas oxygen.
 - (v) All lbs/MMBtu NOx emission rates shall be calculated as pounds of nitrogen dioxide per MMBtu of heat input.
 - (vi) All emission concentrations and emission rates shall be based on hourly averages.
- [District Rule 1302]

8.Records and Reporting (Rule 1157(E)(2)):

The owners/operators shall monitor and record for each permit the HHV and cumulative annual usage of fuel. The cumulative annual usage of fuel shall be monitored from utility service meters, purchase or tank fill records, or by any other acceptable methods, as approved by the Air Pollution Control Officer. A statement of the heat input for the previous calendar year shall be submitted to the District by May 31st of each year; reports shall be submitted via e-mail to reporting@mdaqmd.ca.gov.
[District Rule 1302]

9.Test Methods (Rule 1157(F)):

(A) Compliance with the NOx, carbon monoxide and oxygen requirements shall be determined using the following test methods:

- (a) Oxides of Nitrogen - EPA Method 7E or ARB Method 100
- (b) Carbon Monoxide - EPA Method 10 or ARB Method 100
- (c) Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100
- (d) NOx Emission Rate (Heat Input Basis) - EPA Method 19

(B) HHV determination shall be by one of the following test methods:

- (a) ASTM D 2015-85 for solid fuels; or
- (b) ASTM D 240-87 or ASTM D 2382-88 for liquid hydrocarbon fuels; or
- (c) ASTM D 1826-88, or ASTM D 1945-81 in conjunction with ASTM D 3588-89 for gaseous fuels; or
- (d) as provided by the fuel supplier.

[District Rule 1302]

10.This facility is an SM-80 synthetic minor facility for NOX and VOC emissions and as such the emissions shall not exceed the following emission limits:

- a. NOx emissions shall not exceed 20 TPY, and
- b. VOC emissions shall not exceed 20 TPY.

PM-10 emissions are limited to no more than 93,437 pounds per year (46.72 TPY). It is noted that PM-10 emissions have been fully offset to this amount through a series of previous NSR activities.

[District Regulation XIII]

11. This facility shall not emit more than 9.9 t/y of a single HAP and 24.9 t/y of all HAP's. To ensure compliance, the owner/operator shall calculate and record the annual emissions of Federal Hazardous Air Pollutants (HAP's) in tons per year (t/y) on a calendar year basis (January 1 through December 31). The list of HAP's can be found in Section 112(b)(1) of the Federal Clean Air Act or at web site:

<http://www.epa.gov/ttn/atw/188polls.html>.

[District Rule 1302]

12. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request. [District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]