



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B010878

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: OCTOBER 2010

OWNER OF OPERATOR (Co.#1535)

Boeing Company - Victorville Ops
18200 Phantom West, Ste 678-2
Victorville, CA 92394-7911

EQUIPMENT LOCATION (Fac.#2607)

Boeing - Victorville
18200 Phantom West, Ste 678-2
Victorville, CA 92394-7911

Description:

DIESEL IC ENGINE, PORTABLE GENERATOR consisting of: Year of Mfg. 2007, USEPA Tier 3, Engine family name 7CEXL0661AAF, CARB E.O. # U-R-002-0378, diesel PM level 0.08 g/bhp-hr

One Cummins, Diesel fired internal combustion engine Model No. QSM11 and Serial No. TBD, After Cooled, Direct Injected, Turbo Charged, producing 400 bhp with 6 cylinders at 1800 rpm while consuming a maximum of 21.0 gal/hr. This equipment powers a NET Generator Model No. MDG-5-225-C and Serial No. 625018-2, rated at 180 KVA.

EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	0.68	gm/bhp-hr
NOx	2.42	gm/bhp-hr
PM10	0.08	gm/bhp-hr
SOx	0.006	gm/bhp-hr
VOC	0.43	gm/bhp-hr

CONDITIONS:

1. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles, which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

2. This diesel ICE and its associated equipment cannot be operated at the same footprint (spot) for more than 365 consecutive days.

Fee Schedule: 1 (c) Rating: 400 bhp SIC: 3721 SCC: 20100102 Location/UTM(Km): 473E/3820N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Boeing Company - Victorville Ops
4000 Lakewood Blvd.

Long Beach, CA 90808

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

(This system must be moved within this facility or moved to another facility annually.)

3.This unit shall only be fired on ultra-low sulfur diesel fuel, whose sulfur concentration is less than or equal to 0.0015% or 15 ppm on a weight per weight basis per CARB Diesel or equivalent requirements.

4.A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.

5.This engine shall not be operated for more than 1000 hours in any calendar year.

6.The o/o shall maintain a operations log for this unit current and on-site (or at a central location) for a minimum of three (3) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:

- a. Calendar year operation in terms of fuel consumption (in gallons) and total hours; and,
- b. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log).

7.The o/o of this unit must submit a Status Report for the entire fleet* by March 1, 2011. This Status Report should include, but not limited to, the following, for details see Title 17 CCR 93116.4(e)(1):

- a. The fleet's weighted average PM emission rate for the 2010 calendar year,
- b. Inventory of portable engines in the fleet,
- c. Identify, if applicable, each portable diesel-fueled engine that the owner commits to replacing with a Tier 4 engine,
- d. Listing of portable diesel-fueled engines, if applicable, used exclusively in emergency applications,
- e. Listing of portable diesel-fueled engines, if applicable, satisfying the low-use engine requirements,
- f. Listing of portable alternative-fueled engines, if applicable, added to the fleet prior to January 1, 2009, pursuant to section 93116.3(d)(2)(B)2, and
- g. Listing of portable diesel-fueled engine(s) equipped with Selective Catalytic Reduction (SCR) system(s),

* Fleet is defined in Title 17 CCR Section 93116.2(p) as one or more portable unit(s). 8

8.The o/o and/or Responsible Official of a fleet electing to use electrification in determining the fleet average shall submit the report required by Title 17 CCR 93116.4(c)(3) by January 1, 2012.

9.The fleet under control of this o/o is subject to and shall comply with the weighted PM emission fleet averages expressed as grams per brake horsepower-hour (g/bhp-hr) by the listed compliance dates in Title 17 CCR Section 93116.3(c).

Fleet Standard Compliance;

Engines <175 bhp Engines >175 to 749 bhp Engines >750 bhp

Date (g/bhp-hr) (g/bhp-hr) (g/bhp-hr)

1/1/2013 0.3 0.15 0.25

1/1/2017 0.18 0.08 0.08

1/1/2020 0.04 0.02 0.02

Fleet is defined in Title 17 CCR Section 93116.2(16).

10.The o/o of this unit must submit a Statement of Compliance signed by the Responsible Official that the fleet standards are being achieved and a summary that identifies each portable engine in the fleet and the associated emission rate (g/bhp-hr) and other required information, see Title 17 CCR 93116.4(e)(2), (3), (4), (5), (6) and (7) for the following compliance statement submittal dates:

Weighted DPM Emission Fleet Average Date Submit by

January 1, 2013 March 1, 2013

January 1, 2017 March 1, 2017

January 1, 2020 March 1, 2020

11. This unit is subject to the requirements of the Airborne Toxic Control Measure For Diesel Particulate Matter From Portable Engines Rated At 50 Horsepower and Greater (Title 17 CCR 93116). In the event of conflict between these conditions and the ATCM, the more stringent requirements of the ATCM shall govern.