

## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park AvenueVictorville, CA92392-2310 760.245.1661 -- 800.635.4617 -- FAX760.245.2022

## PERMIT TO OPERATE

B011694

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

### **EXPIRES LAST DAY OF: NOVEMBER 2025**

# OWNER OF OPERATOR (Co.#453)

Victor Valley Wastewater Reclamation Authority 20111 Shay Road Victorville,CA92394

# **EQUIPMENT LOCATION (Fac.#3406)**

VVWRA - Hesperia WRP 10567 Appaloosa Ave Hesperia, CA92345

#### **Description:**

WATER RECLAMATION PLANT, SCALPING FACILITY consisting of:

#### **EQUIPMENT**

Capacity	Equipment Description
0	Influent Flow Meter, Magnetic type
1	Headworks
2	Two Headworks-Fine Screening-Rotary Drums, 1 HP each
6	Two Headworks-Screenings Washers and Compactors, 3 HP each
0	Aeration Basins-Two Parallel Basins
400	Aeration Blowers; Two Blowers-2 Duty, 1 Standby, Each Rated 200 HP. Note: Standby not included for fee purposes
110	Feed Forward Pump Station; Three Pumps- 2 Duty, 1 Standby, Each Rated 55 HP
0	Feed Forward Wet Well
0	Waste Activated Sludge (WAS) Wet Well
10	WAS Pumps; Two Pumps- 1 Duty, 1 Standby, Each Rated at 10 HP
0	WAS Flow Meter
7	Misc Uses; Process Drain Sump Pump (5 HP), Reclaimed Wet Well Sample Pumps (1 HP), Chem Containment Sump Pump (1 HP)
0	Membrane Filtration System (Two Trains); Hollow Fiber Submerged Membranes
Schedule:7 (i)	Rating:1device SIC:4952 SCC:50100701 Location/UTM(Km):473

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Victor Valley Wastewater Reclamation Authority P.O. Box 370 Adelanto, CA92301

By: COPY

Brad Poiriez

Air Pollution Control Officer

Capacity	Equipment Description
100	Membrane Permeate/Backpulse Pumps; Two Total (One Per Train) Each Rated at 50 HP
80	Membrane Air, Agitation Air Blowers; Three Total- Two Duty, One Standby, Each Rated at 40 HP
0	Membrane Chemical Feed Systems; Sodium Hypochlorite Storage Tank (6,750 gal), Citric Acid Storage Tote (275 gal)
0	UV Disinfection System
80	Reclaimed Water System; Storage, Pumping- One Duty (60 HP), One Standby (60 HP), Plant Water Pumping- One Duty (20 HP) One Standby (20 HP)
1	Headworks Building Water Heater (TBD BTU)
1	Fine Screen Lube Oil Pumps
10	Air Compressor, 10 HP
7.59	HVAC systems
24	Anoxic Mixers, Six Total, Each Rated at 4 HP.
0	Storm Water Pumps, Two Total, Each Rated at
3	Citric Acid Feed Pumps, Two Total, Each Rated at 1.5 HP.
5.1	Sodium Hypochlorite Feed Pumps, 7 Total. 2 Rated at 1.5 HP. One rated at 0.75 HP. 4 rated at 0.33 HP.

## **CONDITIONS:**

- 1. This equipment shall only be installed, operated and maintained in strict accordance with manufacturer/supplier recommendations and/or federal, state, regional and local waste water discharge permits. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit. Specifically, this equipment must be operated concurrently with the equipment described in District Permit C011693, and must achieve the manufacturer's designed Hydrogen Sulfide (H2S) control efficiency of 97 percent or higher. [District Rules 203 and 1302]
- 2. This facility shall not treat more than 1.0 million gallons of waste water in any one day, averaged over any thirty day period. [District Rule 1302]
- 3. This equipment shall be in operation and fully functional whenever the facility is processing wastewater influent or screening wastewater materials.

  [District Rule 1302]
- 4.A flow indication device shall be installed to measure and record the wastewater throughput for each day of operation. [District Rules 1303 and 1320]
- 5.The owner/operator shall conduct odor surveys (smell test) at the facility's downwind property line and at the facility's property line closest to the nearest residence on a monthly basis or more frequently if requested to do so by the District. Any detection of odor shall be documented and corrective action shall be taken within 24 hours to reduce the odors at the property line(s) to below detectable limits. [District Rule 402]
- 6. The owner/operator shall maintain a log onsite which includes at a minimum:
- a. Date and time of all malfunctions, maintenance, and repairs to the system;
- b. Copies of all odor complaints and corrective actions taken; and
- c. Results of all property line odor surveys and corrective actions taken if necessary. This log shall be maintained onsite for a minimum of two years and made available to District, State, or Federal compliance personnel upon request. [District Rule 1302]
- 7.A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

  [District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]

Page 2 of 2 Permit:B011694 Issue Date:11/14/2024