



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

AUTHORITY TO CONSTRUCT

B013397

If construction is not completed by the expiration date of this permit, it may be renewed for one additional year upon payment of applicable fees. Any additional extension will require the written approval of the Air Pollution Control Officer. This Authority to Construct may serve as a temporary Permit to Operate provided the APCO is given prior notice of intent to operate and the Permit to Operate is not specifically denied.

EXPIRES LAST DAY OF: JUNE 2026

OWNER OF OPERATOR (Co.#2502)

Castle Mountain Venture
980 American Pacific Dr., Suite 102
Henderson, NV 89014

EQUIPMENT LOCATION (Fac.#3896)

Castle Mountain Mine
115575 Hart Mine Road
Ivanpah, CA 92364

Description:

DIESEL IC ENGINE, RAW WATER WELL W-02 PORTABLE* GENERATOR #2 consisting of: Model Year 2019, EPA Tier 4F, EPA Engine Family KSZXL07.8QXB, CARB EO U-R-006-0475 Stack Data Height: 7.5 ft Diam.: 0.42ft Temp.: 756 F ACFM: 961 *Please note, this equipment complies with the stationary requirements of 17 CCR 93115 and 40 CFR 60, Subpart IIII and may be operated at various locations at this facility.

One Isuzu, Diesel fired internal combustion engine Model No. BQ-6HK1X and Serial No. 6HK1-939415196HF04, Direct Injected, Turbo Charged, After Cooled, Selective Catalytic Reduction, Exhaust Gas Recirculation, Exhaust Gas Recirculation, Diesel Oxidation Catalyst, Electronic Control Module, Selective Catalytic Reduction, Ammonia Oxidation Catalyst, producing 227.3 bhp with 6 cylinders at 1800 rpm while consuming a maximum of 13 gal/hr. This equipment powers a Shindaiwa Generator Model No. SSG-3180SI and Serial No. D18401000054, rated at 144 kW.

EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	0.00	gm/Kw-hr
NOx	0.27	gm/Kw-hr
PM10	0.01	gm/Kw-hr
PM2.5	0.01	gm/Kw-hr
SOx	0.006	gm/Kw-hr
VOC	0.01	gm/Kw-hr

Fee Schedule: 1 (c)

Rating: 227 bhp

SIC: 1041

SCC: 20200102

Location/UTM(Km):
672E/3905N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Castle Mountain Venture
980 American Pacific Dr.

Henderson, NV 89014

By: **COPY**

Eldon Heaston

Air Pollution Control Officer

CONDITIONS:

1. This certified Tier 4 Final stationary compression-ignited internal combustion engine and its associated emission control systems shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of air contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

[40 CFR 60.4211(a)]

2. This engine shall not be operated unless all of the following engine emission systems are properly functioning:

- a. Engine Control Module
- b. Exhaust Gas Recirculation
- c. Diesel Oxidation Catalyst
- d. Selective Catalytic Reduction
- e. Ammonia Slip Catalyst

Furthermore, no changes shall be made to any of the above systems unless done so by a factory certified technician.

[District Rule 1302]

3. This equipment shall only be fired on diesel fuel that meets the following requirements, or an alternative fuel approved by the ATCM for Stationary CI Engines:

- a. Ultra-low sulfur concentration of 0.0015% (15 ppm) or less, on a weight per weight basis; and,
- b. A cetane index or aromatic content, as follows:
 1. A minimum cetane index of 40; or,
 2. A maximum aromatic content of 35 volume percent.

[17 CCR 93115.5(a), 40 CFR 80.510, and 40 CFR 60.4207(b)]

Note: Use of CARB certified ULSD fuel satisfies the above requirements.

4. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.

[17 CCR 93115.10(d)(1) and 40 CFR 60.4209(a)]

5. Owner/operator shall conduct inspection, whichever is more frequent of, at least once every calendar quarter; or, after every 2,000 hours of engine operation. An inspection includes any testing, maintenance, and/or other procedures that ensure the Internal Combustion Engine is operated in strict accordance with the manufacturer's specifications and in continual compliance with the provisions of this rule.

[District Rule 1302]

6. The owner/operator shall maintain an operations log for this unit, current and on-site (or at a central location), for a minimum of five (5) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:

- a. Quarterly fuel use and quarterly hours of operation, on a calendar quarter basis;
- b. The date and a summary of each engine inspection including any testing and maintenance performed.
- c. Fuel sulfur concentration (may use the fuel supplier's certification of sulfur content if it is maintained as part of this log).

[17 CCR 93115, District Rules 1302 and 1320]

7. This engine is subject to the requirements of Title 17 CCR 93115, the Airborne Toxic Control Measure (ATCM) for Stationary Compression Ignition Engines and 40 CFR 60, Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (NSPS). In the event of a conflict between these conditions and the ATCM or NSPS, the more stringent requirements shall govern.

[District Rule 1302]

8. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]