



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

B013480

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: JUNE 2020**

**OWNER OF OPERATOR (Co.#2482)**

Zohnson & Co.  
4195 Chino Hills Parkway, #171  
Chino Hills, CA 91709

**EQUIPMENT LOCATION (Fac.#3876)**

Zohnson & Co.  
17277 Columbus Street  
Adelanto, CA 92301

**Description:**

DIESEL IC ENGINE, PORTABLE GENERATOR consisting of: Year of Mfg. 2013, EPA Tier 4i, Engine Family TBD, CARB EO No. TBD: Stack Data; H: 8' Diam: 0.5" Temp:

One Cummins, Diesel fired internal combustion engine Model No. QSB7G6 and Serial No. TBD, Turbo Charged, After Cooled, Exhaust Gas Recirculation, Diesel Particulate Filter, Exhaust Gas Recirculation, producing 268 bhp with 6 cylinders at 1800 rpm while consuming a maximum of 13.5 gal/hr. This equipment powers a Aggreko Generator Model No. QSB7G6 and Serial No. TBD, rated at 200 kW.

**EMISSIONS RATES**

Emission Type	Est. Max Load	Unit
CO	2.63	gm/bhp-hr
NOx	1.5	gm/bhp-hr
PM10	0.015	gm/bhp-hr
PM2.5	0.015	gm/bhp-hr
SOx	0.005	gm/bhp-hr
VOC	0.14	gm/bhp-hr

**CONDITIONS:**

1. This certified diesel fired internal combustion engine shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles, which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted

Fee Schedule: 1 (c)

Rating: 268 bhp

SIC: 2833

SCC: 20100102

Location/UTM(Km):  
459E/3825N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Zohnson & Co.  
4195 Chino Hills Parkway, #171  
Chino Hills, CA 91709

By: **COPY**  
**Eldon Heaston**  
Air Pollution Control Officer

with the application for this permit.  
[District Rule 204 and 1302]

2. This engine shall not be operated unless all of the following emission control systems are properly functioning:

- a. Diesel Oxidation Catalyst;
- b. Electronic Control Module;
- c. Exhaust Gas Recirculation System;
- d. Selective Catalytic Reduction (SCR) system; and
- e. Ammonia Oxidation Catalyst system

Furthermore, no changes shall be made to any of the above systems unless done so by a factory certified technician.  
[District Rule 1302]

3. This diesel ICE and its associated equipment cannot be operated at the same engine-print (spot) for more than 365 consecutive days. (This system must be moved for a valid business purpose within this facility or moved to another facility annually.)

[Title 17 CCR 93116.2(bb)]

4. This unit shall only be fired on ultra-low sulfur diesel fuel whose sulfur concentration is less than or equal to 0.0015% (15 ppm) per CARB Diesel or equivalent requirements; or alternative diesel fuel or CARB diesel fuel utilizing fuel additives that has been verified through the Verification Procedure for In-Use Strategies to Control Emissions from Diesel Engines.

[Title 17 CCR 93116.3(a)]

5. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.

[Title 17 CCR 93116.4(c)(2)(A)]

6. The owner/operator shall maintain an operations log for this unit current and on-site (or at a central location) for a minimum of five (5) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:

- a. Date of each use and duration of each use (in hours);
- b. Location of use, to demonstrate that this equipment meets the requirements of 17 CCR 93116.2(bb);
- c. Calendar year operation in terms of fuel consumption (in gallons) or total hours;
- d. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log); and
- e. Records of any corrective action taken after digital engine monitoring has notified the owner or operator of malfunction.

[Title 17 CCR 93116.4(c)]

7. This portable equipment shall not be operated and/or located within 1000 feet of a public or private school (kindergarten through 12th grade) of more than 12 students for more than 45 consecutive days without completing the notification required by Health and Safety Code 42301.6.

8. The fleet of portable diesel IC engines under control of this owner/operator is subject to, and shall comply with, the requirements of the Portable Diesel ATCM (Title 17 CCR 93116).

9. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]