



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B013796

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: MARCH 2024

OWNER OF OPERATOR (Co. #2261)

Clark Pacific Precast, LLC
9367 Holly Rd.
Adelanto, CA 92301

EQUIPMENT LOCATION (Fac. #3628)

Clark Pacific Adelanto Precast Plant
9367 Holly Rd.
Adelanto, CA 92301

Description:

NATURAL GAS, HOT WATER HEATER consisting of: a Sioux Corporation Model M-1 hot water heater equipped with two Power Flame Model M-2 natural gas fired burners each rated 1.15 MMBtu/Hr. Each burner stack is 20 feet high and 12 inch diameter.

CONDITIONS:

1. This equipment shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or in a manner consistent with safety and good air pollution control practices for minimizing emissions. Furthermore, operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued.
[District Rule 1302]

2. This equipment is limited to using only commercially available natural gas for fuel.
[District Rule 431]

3. The owner/operator shall maintain an operations log for this equipment on-site and current for a minimum of two (2) years, and said log shall be provided to District personnel on request. The operations log shall include the following information at a minimum:
a. Records of all maintenance, repairs, and tune-ups; and,
b. Total fuel consumed on an annual basis: Fuel consumption can be calculated based on fuel purchase records, dedicated fuel meter readings, or other District approved method.
[District Rule 1520]

4. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

Fee Schedule: 2 (c) Rating: 2300000Btu SIC: 3272 SCC: 10200603 Location/UTM(Km): 459E/3826N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Clark Pacific Precast, LLC
710 Riverpoint Court

West Sacramento, CA 95605

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

