



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B014763

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: JUNE 2025

OWNER OF OPERATOR (Co.#2500)

5E Boron Americas, LLC
9329 Mariposa Rd. Suite # 210
Hesperia, CA 92344

EQUIPMENT LOCATION (Fac.#3893)

5E Boron Americas, LLC
27555 Hector Road
Newberry Springs, CA 92365

Description:

TEMPORARY UTILITY BOILER consisting of: A Wyssmont model TBD natural gas fueled utility boiler, serial number TBD, rated at 425 bhp with a maximum heat input of 17.86 MMBtu/hour. The boiler is heated via a PowerFlame model UCM500-G-30NFT Low-NOx Burner, operating at a maximum temperature of 644 degrees Fahrenheit. This boiler consumes approximately 17,010 cubic feet of natural gas per hour and has an exhaust flow of approximately TBD acfm at TBD degrees Fahrenheit through a TBD foot high by TBD foot diameter stack.

CONDITIONS:

1. This equipment shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit. [District Rules 204 and 1303]
2. This boiler shall only be fueled with PUC-Regulated pipeline quality natural gas. A dedicated fuel meter shall be installed to directly measure fuel usage. [District Rules 431, 1157 and 1303]
3. The four boilers described in District Permits B013328, B013329, B013330 and B014763 combined shall consume no more than 3,700 MMSCF of natural gas in any consecutive twelve month period. [District Rules 1302 and 1303]

Fee Schedule: 2 (e)

Rating: 17860000 Btu

SIC: 1479

SCC: 10200603

Location/UTM(Km): 552E/3846N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

5E Boron Americas, LLC
9329 Mariposa Rd. Suite # 210
Hesperia, CA 92344

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

4.This boiler shall not operate concurrently with the three boilers described in District Permits B013328, B013329, and B013330.
[District Rules 1302 and 1303]

5.The natural gas burner shall not exceed the following emission limits as verified by the source tests required in Condition #6:
a. NOx: No more than 7 ppmvd measured as NO₂ at 3% O₂ nor more than 0.008 lb/MMBtu;
b. CO: No more than 50 ppmvd measured at 3% O₂ nor more than 0.039 lb/MMBtu;
[District Rules 1157, 1303, and 1320]

6.The owner/operator must conduct an initial performance test (source test) for NOx and CO within 60 days of achieving full production rate, but in no case later than 180 days after initial startup. Additionally, annual source tests for NOx and CO shall be conducted at least once in every 12 month period following the most current test date.

The NOx source test must be conducted in accordance with USEPA Method 7E or CARB Method 100, the CO source test must be conducted in accordance with USEPA Method 10 or CARB Method 100, and the Stack Gas Oxygen must be measured in accordance with USEPA Method 3 or 3A or ARB Method 100. All tests must be conducted while the furnace is running at a minimum load of 90%.

The owner/operator must submit a source test protocol at least thirty (30) days prior to the scheduled source test date for District review and approval, and the owner/operator must conduct all required tests in accordance with the District-approved test protocol.

The owner/operator must notify the District a minimum of ten (10) days prior to the first day of testing so that an observer may be present.

The final source test results must be submitted to the District within forty-five (45) days of completion of the test. All compliance/certification test notifications, protocols, and results may be submitted electronically to reporting@mdaqmd.ca.gov
[District Rules 204, 1157(E)(1), and 1320; 40 CFR 60.8]

7.Emissions from the entire facility shall not exceed the following limits:
a. Oxides of Nitrogen (NOx): 24 tons per consecutive twelve month period, measured as NO₂;
b. Oxides of Sulfur (SOx): 24 tons per consecutive twelve month period;
c. Volatile Organic Compounds (VOC): 24 tons per consecutive twelve month period;
d. Carbon Monoxide (CO): 95 tons per consecutive twelve month period;
e. Hydrogen Sulfide (H₂S): 9.5 tons per consecutive twelve month period;
f. Lead (Pb): 0.5 tons per consecutive twelve month period;
g. Particulate Matter 10 microns and less (PM₁₀): 14.5 tons per consecutive twelve month period;
h. Any single Hazardous Air Pollutant (HAP): 9.5 tons per consecutive twelve month period; and
i. All HAPs combined: 24 tons per consecutive twelve month period.

Compliance shall be demonstrated to the District through the submission of a District approved Comprehensive Emission Inventory Report (CEI) or other equivalent and District approved method.
[District Rules 1302 and 1320]

8.In the event of a malfunction of any emissions related part of this boiler, the unit must be shut down as soon as safely possible and shall not be restarted until all malfunctions have been corrected. Equipment breakdowns shall be reported to the District in accordance with District Rule 430.
[District Rules 430 and 1302]

9.The owner/operator must maintain an operations log for this equipment. This log shall be maintained current, kept for a total of five (5) years and be provided to authorized personnel upon request. The log shall contain the following at a minimum:
a. The monthly cumulative natural gas usage for the four boilers described in District Permits B013328, B013329, B013330, and B014763, in MMSCF.
b. Consecutive rolling 12 month period cumulative natural gas usage for the four boilers described in District Permits B013328, B013329, B013330, and B014763, in MMSCF.
c. Times and durations of malfunctions, a description of each malfunction, and the corrective action taken for each malfunction.
d. The results of all initial, annual, and all subsequent source tests.
e. Fuel sulfur concentration (the owner/operator may use the supplier's certification of sulfur content if it is maintained as part of this log).
[District Rules 1157 and 1302]

10.A statement certifying the total heat input for this boiler for the previous calendar year shall be submitted to the District no later than March first each year. The District's default value for the High Heating Value of natural gas is 1020 Btu/scf. This statement may be submitted electronically to reporting@mdaqmd.ca.gov
[District Rule 1157(E)(2)(a)]

11.A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.
[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]