



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

C000006

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: JUNE 2026

OWNER OF OPERATOR (Co.#1)

CEMEX Construction Materials Pacific LLC
16888 North E Street
Victorville, CA 92392

EQUIPMENT LOCATION (Fac.#6)

CEMEX - River Plant
16888 North E Street
Victorville, CA 92392

Description:

BAGHOUSE (JBH-2) consisting of: Serves Raw Material Receiving Conveyors (B001288). Reverse pressure cleaning SWPC type MK V fabric duster collector, two-compartment, with 144 6-1/8" dia x 150" long filament dacron sateen bags with American Standard 15 MH Series 106 exhauster - JBH2 A/C ratio: 1.74:1, 2,880 ft², 5,000 cfm Facility has specified that the normal operating range for pressure differential is between 2 and 6 inches water column.

CONDITIONS:

1. The owner/operator (o/o) shall maintain this baghouse in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of air contaminants.
[District Rule 204]

2. This baghouse shall be operated concurrently with the Raw Material Receiving Conveyors under District Permit B001288.
[District Rule 204]

3. The o/o shall conduct a minimum program of inspection and maintenance on this equipment, following the operations and maintenance plan requirements pursuant to 40 CFR 63, Subpart LLL. The o/o shall maintain current and on-site for five (5) years a log of the following information, which shall be provided to District personnel upon request:

- a. A site-specific opacity monitoring plan;
- b. Pressure differential across the bags (monthly);
- c. Bags and bag suspension system inspection (annually);
- d. Monthly baghouse stack observations using USEPA Method 22 (10-minute test), and USEPA Method 9 (30 minutes of observations)

Fee Schedule: 7 (h)

Rating: 1 device

SIC: 3241

SCC: 30500609

Location/UTM(Km): 472E/3823N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

CEMEX Construction Materials Pacific
LLC
16888 North E Street
Victorville, CA 92392

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

if visible emissions are observed. If no visible emissions are observed for six consecutive months, the frequency can change to semi-annually. If no emissions are observed semi-annually the frequency can be changed to annually. If any visible emissions are observed, the frequency reverts to monthly until no visible emissions are observed for six consecutive months.

e. Date and nature of any system repairs.

[40 CFR 63.1350(f), 1355(g)]

4.All equipment shall be operated in compliance with applicable requirements of 40 CFR 63 Subpart LLL - National Emission Standard for Hazardous Air Pollutants from the Portland Cement Manufacturing Industry.

[40 CFR Part 63 Subpart LLL]

5.This baghouse shall not discharge into the atmosphere an exhaust stream that exhibits greater than ten percent opacity.

[District Rule 401; 40 CFR 63.1343(b), 1345]

6.Particulate emissions shall not exceed a discharge grain loading of 0.02 gr/ACF of TSP. This equipment does not require a regularly scheduled emission compliance test. However, emission compliance testing may be required at the discretion of the District.

[District Rules 204 and 1303]

7.The o/o shall maintain on-site, as a minimum, an inventory of replacement bags that assures compliance with applicable Rules of District Regulation IV.

[District Rule 204]