



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

### RENEWAL

C002125

Renewal type Permit has no description information.

**EXPIRES LAST DAY OF: JULY 2025**

#### **OWNER OF OPERATOR (Co.#9)**

Searles Valley Minerals Operations, Inc  
13200 Main Street  
Trona, CA 93562

#### **EQUIPMENT LOCATION (Fac.#79)**

SVM - Argus Facility  
82090 First Street  
Trona, CA 93562

#### **Description:**

BAGHOUSE, COAL RECLAIM SYSTEM consisting of: Serving Crushers Nos. 1 and 2 - Coal Reclaim System (B000521) - McNally Systems, Inc. - Model N: Sonair Jet 1015-150-2355; 2,355 ft<sup>2</sup> cloth area w/5.09:1 A/C ratio - gas flow at ambient degrees F and 12,000 ACFM.

#### **CONDITIONS:**

1. The owner/operator shall have a maintenance plan for this baghouse. This plan, at a minimum, requires a log that includes visual emission readings on a regular basis, recording of differential pressures across the baghouse and inspection/repairs frequency.  
[District Rule 204]

2. The owner/operator shall conduct a minimum program of inspection and maintenance on this equipment. The owner/operator shall maintain current and on-site for five (5) years a log of the following information, which shall be provided to District personnel upon request:

- (a) Daily reading of baghouse pressure drop (date and value);
- (b) Monthly baghouse stack observation date and result (using USEPA Method 22, and USEPA Method 9 when visible emissions are detected), as outlined in condition 9;
- (c) Annual bag and bag suspension system inspection (date and results);
- (d) Date of bag replacements, and
- (e) Date of any excursion, a description of corrective action, and proof of reporting as required by condition 8.

[District Rule 204; 40 CFR 64]

3. The owner/operator shall maintain on-site, as a minimum, an inventory of replacement bags that assures compliance with applicable Rules of District Regulation IV.

Fee Schedule: 7 (h)

Rating: 1 device

SIC: 1474

SCC: 30510103

Location/UTM(Km): 465E/3958N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Searles Valley Minerals Operations, Inc  
P.O. Box 367  
Trona, CA 93592-0367

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer

4.This baghouse shall be operated and maintained in strict accord with manufacturer's and/or supplier's recommendations and/or sound engineering principles.

[District Rule 204]

5.This baghouse shall be operated within the following design specifications when coal is being transferred: maximum outlet particulate concentration and mass emission rate shall not exceed either 0.003 gr/ACF (at nominal maximum flow rate of 12,000 ACFM) or 0.314 lb/hr, respectively.

[District Rule 1303(A) - BACT]

6.The owner/operator shall conduct compliance tests relative to District Rules 404 and 405. Testing must be conducted at least once every sixty (60) months starting in 1994.

Compliance tests must be performed in accordance with the District Compliance Test Procedural Manual. The owner/operator must submit a compliance/certification test protocol at least thirty (30) days prior to the compliance/certification test date. The owner/operator must conduct all required compliance/certification tests in accordance with a District-approved test protocol. The owner/operator must notify the District a minimum of ten (10) days prior to the compliance/certification test date so that an observer may be present. The final compliance/certification test results must be submitted to the District within forty-five (45) days of completion of the test. All compliance/certification test notifications, protocols, and results may be submitted electronically to [reporting@mdaqmd.ca.gov](mailto:reporting@mdaqmd.ca.gov)

[District Rules 404, 405 and 1303(A) - BACT]

7.An additional compliance test shall be performed within 90 days of initial operation of the Refined Coal treatment System. This test shall show compliance with Conditions 5 and 6. Testing shall be carried out in accordance with District Compliance Test Procedural Manual.

[District Rule 204]

8.The pollutant-specific emissions unit (B000521), for which this baghouse controls is subject to the requirements of Compliance Assurance Monitoring (CAM) of 40 CFR 64. As such this permit unit must be in compliance with an approved CAM Plan. An excursion of the CAM Plan is defined as a differential pressure outside the range of 2 to 6 inches of column; and/or, the presence of visible emissions, as demonstrated by condition 9. Any excursion of the CAM Plan requires the owner operator to do the following:

- (a) Inspect the affected equipment,
- (b) Initiate a corrective action, within 24 hours; and,
- (c) Report/Document the excursion in the log book required under condition 2.

[40 CFR 64.7(d)]

9.The owner/operator must conduct monthly 6-minute visible emissions inspections using EPA Method 22. The Method 22 test shall be conducted while the baghouse is operating. The test is successful if no visible emissions are observed. If any visible emissions are observed, the owner/operator of the affected facility must initiate corrective action within 24 hours to return the baghouse to normal operation. The owner/operator must record each Method 22 test, including the date and any corrective actions taken, in the logbook required under condition 2.

[40 CFR 64.7(a)]