



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

### PERMIT TO OPERATE

C002396

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

#### EXPIRES LAST DAY OF: DECEMBER 2025

#### OWNER OF OPERATOR (Co. #629)

Specialty Minerals, Inc  
6565 Meridian Road  
Lucerne Valley, CA 92356

#### EQUIPMENT LOCATION (Fac. #262)

Specialty Minerals, Inc  
6565 Meridian Road  
Lucerne Valley, CA 92356

#### Description:

BAGHOUSE - DCL 72 (METSTONE RAIL/TRUCK LOADOUTS) consisting of: a baghouse with 16 polyester bags totaling 188 square feet of filter area and a fan producing 940 cfm (for an air to cloth ratio of 5:1).

#### CONDITIONS:

1. The owner/operator (o/o) shall maintain this baghouse in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of air contaminants.

[District Rule 1302(B)(1)(a)]

2. This baghouse shall operate concurrently with the Metstone Rail/Truck Loadout under valid District permit number B000709.

[District Rule 1302(B)(1)(a)]

3. The o/o shall conduct a minimum program of inspection and maintenance on this equipment. The o/o shall maintain current and on-site for five (5) years a log of the following information, which shall be provided to District personnel upon request:

- Weekly baghouse stack observation date and result (using USEPA Method 22, and USEPA Method 9 if necessary);
- Quarterly bag and bag suspension system inspection date and results;
- Quarterly reading of baghouse pressure drop, date and value (if a manometer is present);
- Date of bag replacements; and,
- Date and nature of any system repairs.

[District Rule 1302(B)(1)(a)]

Fee Schedule: 7 (h)

Rating: 1 device

SIC: 1422

SCC: 30502006

Location/UTM(Km): 508E/3803N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Specialty Minerals, Inc  
P.O. Box 558  
Lucerne Valley, CA 92356

By: **COPY**  
Brad Poiriez  
Air Pollution Control Officer

4.This baghouse shall be operated in compliance with 40 CFR 60 Subpart OOO - Standards of Performance for Nonmetallic Mineral Processing Plants.

5.This baghouse shall not discharge into the atmosphere an exhaust stream that exhibits greater than seven percent opacity.  
[40 CFR 60.672(a)(2)]

6.This baghouse shall discharge no more than 0.18 pounds per hour of PM10 at a maximum concentration of 0.022 grains/dscf at the operating conditions given in the above description (40 CFR 60.672(a)(1)). This equipment does not require a regularly scheduled emission compliance test. However, emission compliance testing may be required at the discretion of the District.  
[District Rule 1302(B)(1)(a)]

7.The o/o shall maintain on-site a minimum inventory of replacement bags that assures compliance with these conditions.  
[District Rule 1302(B)(1)(a)]

8.A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.  
[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]