



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

C003300

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: DECEMBER 2006

OWNER OF OPERATOR (Co.#500)

ACE Cogeneration Company
12801 S Mariposa Street
Trona, CA 93562

EQUIPMENT LOCATION (Fac.#1051)

ACE Cogeneration Company
12801 S Mariposa Street
Trona, CA 93562

Description:

BAGHOUSE consisting of: Bin vent serving Fly Ash Storage Silo (B002131), Flex-Kleen, model no 84 BVBS-25 II, serial no E32583, 265 square feet of cloth area with a 4:1 air to cloth ratio and a gas flow rate at 275 degrees F of 1060 ACFM maximum.

CONDITIONS:

1. The owner/operator (o/o) shall install, operate and maintain this dust collector in strict accord with those recommendations of the manufacturer/supplier, and sound engineering principles which produce minimum emissions of air contaminants.
2. The o/o shall institute a program of maintenance which embraces at least weekly visible emission determinations, monthly visual inspections of all associated equipment (inclusive of the bags and their suspension systems) and regular (to be determined with experience with this unit) measurements of the pressure differential across the bags.
3. The o/o shall log all the items in 2 above in addition to the bag replacements, repairs and non-scheduled maintenance. The log shall be kept current, on-site for a minimum of 2 years and provided to District personnel on request.
4. The o/o shall maintain an inventory of replacement bags on-site at all times which will ensure compliance with applicable Rules of District Regulation IV.
5. The o/o shall install and maintain a device which measures the pressure differential across the bags if one has not been provided with this unit.

Fee Schedule: 7 (h)

Rating: 1 device

SIC: 4911

SCC: 30510298

Location/UTM(Km):
465E/3958N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

ACE Cogeneration Company
12801 S Mariposa Street
Trona, CA 93562

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

6. This baghouse shall operate concurrently with Fly Ash Storage Silo under valid District permit number B002131.