



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

C005276

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: JUNE 2026

OWNER OF OPERATOR (Co.#1047)

High Desert Power Project, LLC
19000 Perimeter Road
Victorville, CA 92394

EQUIPMENT LOCATION (Fac.#1849)

High Desert Power Project
19000 Perimeter Road
Victorville, CA 92394

Description:

OXIDATION CATALYST 3F-2 consisting of: High temperature oxidation catalyst manufactured by EmeraChem ADCAT CO Oxidation Catalytic Systems located within the combustion turbine generator covered by B005267 designed to minimize emissions of VOC and CO.

CONDITIONS:

1. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.

[District Rules 1302(B)(1)(a) and 1303]
[PSD SE 98-01 3/10]

2. This equipment shall be operated and maintained in strict accord with the recommendations of its manufacturer or supplier and/or sound engineering principles.

[District Rules 1302(B)(1)(a) and 1303]
[PSD SE 98-01 3/10]

3. This equipment shall be operated concurrently with the combustion turbine generator with valid District permit (C005275 serves B005266; C005276 serves B005267 and C005277 serves B005268; as described above).

[District Rules 1302(B)(1)(a) and 1303]
[PSD SE 98-01 3/10]

Fee Schedule: 7 (h)

Rating: 1 device

SIC: 4911

SCC: 20100201

Location/UTM(Km):
473E/3820N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

High Desert Power Project, LLC
ATTN: Accounts Payable

Victorville, CA 92394

By: **COPY**
Eldon Heaston
Air Pollution Control Officer