



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

C010317

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: APRIL 2009

OWNER OF OPERATOR (Co.#46)

Victorville, City of
14343 Civic Drive
Victorville, CA 92392-2399

EQUIPMENT LOCATION (Fac.#2948)

Victorville 2 Hybrid Power Project
Perimeter Road
Victorville, CA 92392

Description:

SELECTIVE CATALYTIC REDUCTION SYSTEM (#2) consisting of: Selective catalytic reduction system with a catalyst located within the power train covered by B010314, and an ammonia injection system. Manufacturer will be specified when available.

CONDITIONS:

1. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
2. This equipment shall be operated and maintained in strict accord with the recommendations of its manufacturer or supplier and/or sound engineering principles.
3. This equipment shall be operated concurrently with the combustion turbine generator with valid District permit B010314.
4. Ammonia shall be injected whenever the selective catalytic reduction system has reached or exceeded 550 degrees Fahrenheit except for periods of equipment malfunction. Except during periods of startup, shutdown and malfunction, ammonia slip shall not exceed 5 ppmvd (corrected to 15% oxygen), averaged over three hours.
5. Ammonia injection by this equipment in pounds per hour shall be recorded and maintained on site for a minimum of five (5) years and shall be provided to MDAQMD personnel on request.

Fee Schedule: 7 (h)

Rating: 1 device

SIC: 4911

SCC: 20100201

Location/UTM(Km):
467E/3828N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

<p>Victorville, City of Public Works - Fleet Division Victorville, CA 92392-2399</p>

By: **COPY**
Eldon Heaston
Air Pollution Control Officer